



HILLARY GITELMAN  
Director

# COUNTY of NAPA

CONSERVATION, DEVELOPMENT AND PLANNING

PATRICK LYNCH  
Assistant Director

## PERMIT APPLICATION AND INITIAL STUDY REQUEST FOR COMMENTS

TO: BUILDING INSPECTION DIVISION  
APPLICATION TITLE: Dina Divo APN: 18-060-069  
DESCRIPTION OF PROJECT: New winery request with production of 10,000 gal per yr.

RESPONSE REQUEST DATE: 10.2.07 RESPONSE RETURN DATE: 10.16.07  
PLEASE RESPOND VIA E-MAIL TO: jmc-dowel@co.napa.ca.us  
OR FAX TO (707) 299- 4082

This application (see enclosed project description and maps) is being sent to you for your review and comment.

With respect to environmental analysis, the County is assuming Lead Agency status for the project and will be preparing the necessary environmental documents.

1. Do you have any comments on this project? ☒ Yes ☐ No
2. Do you have jurisdiction by law over this project? ☒ Yes ☐ No
3. Attach your agencies comments, or list below: ☒ Comments attached ☐ Comments below.

*See printout attached of comments from Aceta*

Name of contact person: Eric Banvard Telephone #: 299-1359  
Email: ebanvard@co.napa.ca.us  
Title: Plan & Permits Supervisor  
Date: 10.14.07



Napa County

Menu | Favorites | Help | Logout | Planning

User ID: EBANVARD

Admin Tools

Daily

ACCELA AUTOMA

SmartManager	Application	Property	People	Fees	Workflow	Attachments	Reports	Condition
--------------	-------------	----------	--------	------	----------	-------------	---------	-----------

## Workflow

Application #: P07-00719

Submit

Application Type: Planning / PL Permits / Use Permit / Use Permit General

Address: 1185 FRIESEN DRIVE, ANGWIN, CA

<ul style="list-style-type: none"><li>✓ Application Acceptance</li><li>• Environmental Review</li><li>• Public Works Review</li><li>• Fire Review</li><li>• EM Review</li><li>• County Council Review</li><li>• Planning Review</li><li>✓ Building Review<ul style="list-style-type: none"><li>Planning Approval</li><li>Closure</li></ul></li></ul>	<p><b>Task Details - Building Review</b></p> <p><b>Assigned Date:</b> 10/03/2007      <b>Due Date:</b></p> <p><b>Assigned To:</b>      <b>Department:</b> Building Department</p> <p><b>Current Status:</b> Approved      <b>Status Date:</b> 10/14/2007</p> <p><b>Action By:</b> Eric Banvard      <b>Department:</b> Building Department</p> <p><b>Status Comment:</b></p> <p>Must obtain all applicable building permits and comply with all applicable code requirements, including relevant accessibility requirements of CBC Chapter 11B; submit complete and appropriate plans, specifications, energy compliance and engineering, etc. when applying for permits.</p> <p>Unclear that kitchen, w/ 6-burner range, adjoining Tasting Room and Terrace areas would only serve employee break functions; could clearly function for public events as well.</p>
--	---

Vt