

Napa County Fire Department Fire Marshal's Office 1199 Big Tree Road St. Helena, CA 94574

pete.munoa@fire.ca.gov

Office: (707) 967-1421 Fax: (707) 967-1474 Cell: (707) 299-7645

> Pete Muñoa Fire Marshal

INTER-OFFICE MEMORANDUM

TO: John McDowell, Conservation, Development, & Planning Dept.

FROM: Pete Muñoa, Fire Marshal's Office

DATE: January 25, 2010

SUBJECT: Piners Ambulance Service Residence

John,

The Fire Marshal's Office has two comments for this project.

- 2A 10BC Rated Fire Extinguishers shall be located within the structure and accessible from a distance not greater than 75 feet from anywhere within.
- UL listed Smoke detectors be located in all rooms and corridors (kitchen and bathroom areas exempt)

As I stated in our initial meeting, the use of this structure to house an ambulance crew would benefit the citizens of Napa County. As there are a limited amount of units distributed throughout the county, I believe it is important to keep this particular station in the proposed vicinity.

Feel free to contact me if you have any questions at 299-7645.

Pete Muñoa