



# INTER-OFFICE MEMO

---

TO: Conservation, Development, and Planning Department

FROM: Alicia Amaro, Fire Department

DATE: April 8, 2009

SUBJECT: Pavitt Winery Use Permit Comments - **Revised**  
Apr: 020-350-026 P06-01426

**Site Address: 4660 Silverado Trail, Calistoga**

The Napa County Fire Marshal staff has reviewed the use permit application to utilize an 3,585 square foot existing barn as a winery. If the project is approved we recommend the following conditions.

**All construction and use of the facility shall comply with all applicable standards, regulations, codes and ordinances at the time of building permit issuance.**

1. An approved automatic fire sprinkler system will be required for all proposed structures 3,600 square feet or greater. The existing structure is just 15 square feet less than the threshold for a sprinkler system therefore a sprinkler system is not required. If square footage is added to the winery facility in the future the facility shall be retrofitted with an automatic fire sprinkler system in accordance with the *National Fire Protection Association Standard (NFPA) #13 (Installation of Sprinkler System, 2002 edition)*. A minimum of 60 minutes of water storage for the sprinkler system will also be required.
2. The ***minimum*** required fire flow for the protection of the proposed project is 200 gallons per minute for 60 minutes duration at 20 pounds residual water pressure with a water storage volume of 12,000 gallons. The fire flow is based on the square footage of the building and the construction type of Type V- I hour.
3. A fire pump may be required to meet the fire flow requirements. The fire pump shall be installed and maintained in accordance to the *National Fire Protection Standard #20 (Installation of Stationary Pumps for Fire Protection 2003 edition)*. Fire pumps are required to be listed and tested by an approved testing agency and are required to be either diesel driven or electric. Electric fire pumps also require a secondary power source.

4. The private fire service mains shall be installed and maintained in accordance to the *National Fire Protection Standard # 24 (Installation of Private Fire Service Mains and Their Appurtenances 2002 edition)*.
5. The location, number and type of fire hydrants connected to the water supply shall be in accordance with the *California Fire Code, 2007 edition*. Fire hydrants shall be placed within 250 feet of all exterior portions of the building.
6. All post indicator valves, control valves, waterflow devices and fire pumps shall be monitored by an approved remote station or central alarm monitoring company. The digital alarm communicator system panel shall be installed and maintained in accordance with the *National Fire Protection Standard #72 (Fire Alarm Code, 1999 edition)*. The alarm panel or key pad must be located at main entrance of the building.
7. Access roads from the public and/or private right-of- ways to the project/ building site shall comply with Napa County Road and Street Standards and shall be reviewed by the Napa County Public Works Department.
8. Fire apparatus access roads shall be provided to within 150' of all portions of a structure. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet at the building site and an unobstructed vertical clearance of not less than 15 feet.
9. Fire apparatus access roads shall be designed and maintained to support the imposed loads of fire apparatus and shall be provided with a surface so as to provide driving capabilities in all weather conditions. Said access shall be provided prior to any construction or storage of combustible materials on site.
10. A rapid emergency key entry system shall be installed at an approved location by the Napa County Fire Marshal's Office on any proposed gates accessing the property.
11. The applicant shall be responsible for maintaining 10 feet of defensible space along each side of the roadway. This defensible space zone shall include the removal of all dead fuel, dry grass mowed to less than four inches in height, the removal or cutting of all brush, the removal of small trees less than 8 inches in diameter and the removal of all ladder fuel on existing trees up to 8 feet in height, within 10 vertical feet of each side of the roadway.
12. A defensible space zone shall be created around all structures. This defensible space zone shall be 100' from all portions of a structure. Flammable vegetation shall be removed and/or modified in the defensible space zone to create a fuel

break that will help protect the structures from an encroaching wildland fire and will protect the surrounding wildland areas from a structure fire originating on-site.

13. The request for beneficial occupancy ***will not*** be considered until all fire and life safety issues have been installed, tested and finalized.
14. The approved address numbers shall be placed by the applicant in such a position as to be plainly visible and legible from the street fronting the property and shall be placed as to be seen from all entrances. Proposed address shall be indicated on the elevation drawings contained within the building plan submittal. The address numbers shall be a minimum of 4" in height, contrasting in color with their background and shall be illuminated.
15. An approved project sign shall be placed at vehicle access points into the project during construction to assist emergency responders. The sign shall identify the project name and address. Such signs shall be clearly visible and legible from the street fronting the project.
16. The applicant shall properly identify all required fire lanes. Fire lanes shall be painted red with white letters to read "NO PARKING FIRE LANE CVC 22500.1, stenciled every 30 feet on top of the curb.
17. An approved access walkway shall be provided to all exterior doors and openings required by either the California Fire Code or the California Building Code. A concrete sidewalk or other approved hard surface will meet the intent of the access walkway requirement. Adequate space adjacent to the access walkway, vertically and horizontally, shall be provided to allow firefighters to access required building openings in order to effectively perform rescue operations, to allow for equipment maneuverability. Any landscaping adjacent to the access walkway shall be such that it does not obstruct the functional purpose of the walkway upon maturity.
18. Buildings with high piled storage exceeding 12 feet in height shall be equipped with smoke and heat vents and curtain boards in accordance with the California Fire Code, Chapter 23, 2007 edition.
19. Firefighter access doors in high piled storage occupancies shall be installed every 100 linear feet per the California Fire Code. Chapter 23, 2007 edition.
20. Currently serviced and tagged fire extinguishers with a minimum rating of 2A10BC shall be provided within 75 feet of travel distance from any portion of the facility and shall be mounted 3 1/2 to 5 feet to the top of the extinguisher.
21. All exit doors shall be operable without the use of a key or any special knowledge or

effort.

22. Illuminated exit signs and emergency back up lighting shall be installed throughout the building per the California Building Code, section 1004, 2007 edition.
23. A Knox Cabinet shall be installed at an approved location by the Napa County Fire Marshal's Office.
24. The Knox Cabinet shall contain the following items:
  1. A minimum of 2 master keys to the structure(s) for emergency access.
  2. 2 scaled site plans of the facility, identifying all buildings, hydrants, fire department access around the facility, and location of all water, electric, and gas shut-off valves.
  3. 2 scaled floor plans of all structures showing doors, offices, etc.
  4. **A digital file of the site plans in a PDF format must be submitted at building final in addition to the hard copies listed above.**
  5. Napa County Hazardous Materials Business including all MSDS forms, etc.
25. A complete set of Building Plans shall be submitted to the Fire Department for review and approval of egress requirements. **The existing sliding doors are not approved exit doors and will need to be replaced with doors that comply with the California Building Code.**
26. Barricades shall be provided to protect any natural gas meter, fire hydrant, or other fire department control device, which may be subject to vehicular damage. Approved signs may be required to identify the location of fire protection devices.
27. Technical assistance in the form of a fire protection engineer or consultant acceptable, and reporting directly, to the NCFD shall be provided by the applicant at **no charge** to the County (California Fire Code section 103.1.1) for independent peer review of alternate methods proposals.
28. Plans detailing compliance with the fire and life safety conditions-of-approval shall be submitted to the Napa County Fire Marshal's Office for review and approval prior to building permit issuance and /or as described above.
29. **A digital file of the site plans in a PDF format must be submitted at building final in addition to the hard copies listed in the condition describing the contents of the Knox Cabinet.**

Alicia Amaro  
Assistant Fire Marshal