

A Tradition of Stawardship A Commitment to Service Alicia Amaro Napa County Fire Asst. Fire Marshal 1199 Big Tree Road St. Helena, CA 94574

alicia.amaro@fire.ca.gov

Main: (707) 967-1425 Fax: (707) 967-1474 Cell: (707) 486-5782

INTER-OFFICE MEMO

TO: Conservation, Development, and Planning Department

FROM: Alicia Amaro, Fire Department

DATE: March 23, 2010

SUBJECT: Napa Commerce Center Comments Apr: 057-210-056 P09-00329 & 330

Site Address: Airport Blvd and Highway 29, Napa

The Napa County Fire Marshal staff has reviewed the plan revisions for the above referenced application.

This application does not warrant additions to fire protection conditions submitted August 21, 2009, as long as all construction and use of the facility complies with all applicable standards, regulations, codes and ordinances at the time of building permit issuance.

If there are any questions please feel free to contact the Napa County Fire Marshal's Office at (707) 967-1425 to discuss any other fire protection issue you may have regarding your project.

Alicia Amaro Assistant Fire Marshal



INTER-OFFICE MEMO

- TO: Hillary Gitelman, Director Conservation, Development, and Planning Department
- FROM: Alicia Amaro, Fire Department
- DATE: August 21, 2009
- SUBJECT: Napa Commerce Center Use Permit Comments Apn: 057-210-056 P09-00329

Site Address: Airport Blvd and Highway 29, Napa

The Napa County Fire Marshal staff has reviewed the plans for the above referenced application. The fire department access roads and turning radius as shown on the plans appear to be adequate. We do request the following revisions on the Utility Plan:

- 1. Show location of the PIV and FDC with hydrants within 50'of FDC.
- 2. Per NFPA 24, hydrants must be located no closer than 40' of any building. Relocate hydrants that do not meet this standard.

If there are any questions please feel free to contact the Napa County Fire Marshal's Office at (707) 967-1425.

Alicia Amaro Assistant Fire Marshal