



A Tradition of Stewardship  
A Commitment to Service

Department of Public Works

1195 Third Street, Suite 201  
Napa, CA 94559-3092  
www.co.napa.ca.us/publicworks


Main: (707) 253-4351  
Fax: (707) 253-4627

Donald G. Ridenhour, P.E.  
Director of Public Works

## PUBLIC WORKS DEPARTMENT INTER-OFFICE MEMORANDUM

**DATE:** August 28<sup>th</sup>, 2010

**TO:** Ron Gee, Conservation Development and Planning Department

**FROM:** Drew Lander, Assistant Engineer 

**SUBJECT:** Ca'Nani Winery, APN 031-120-026, P09-00185UP, P09-00492VAR

The application will allow the establishment of a winery with a production capacity of 48,000 gal/yr in a two-story 16,243sqft winery building; and the construction of 15,970sqft of new cave area. This application proposes 13 full time and 2 part time employees; construct a 44 space parking lot; and provide tours and tasting by appointment only with a maximum of 75 persons/day. Applicant has requested variance to reduce the minimum 600ft winery setback from the state highway.

### EXISTING CONDITIONS:

1. Existing access road currently serves a private residence and exceeds County Road and Street standards for a residential driveway with 12 ft of roadway width and approximately 6 ft of shoulder.
2. The winery site is currently undeveloped.
3. The site is located east of SR29 approximately 500ft South of Yount Mill Road.
4. A two-way center turn lane is existing and serves this parcel access.

### RECOMMENDED CONDITIONS:

#### GROUNDWATER

1. See attached groundwater comments.

## **PARKING:**

2. Any parking proposed by the applicant or required by the Planning Commission as a condition of this use permit must have a minimum structural section equivalent to support an H20 load designed by a licensed Civil or Geotechnical Engineer and shall not be less than two inches of asphalt concrete over 5 inches of Class II Aggregate. (County Road and Street Standards, Page 27, Section 19).
3. Parking lot details shall conform to the requirements of the latest edition of the Napa County Road and Street Standards.
4. Hammerhead turn around area must be delineated with the appropriate signage and/or striping to prevent cars from parking within the turn around.

## **DRIVEWAY:**

5. The access driveway is located south of an opposite driveway which serves an existing winery. Traffic design practice dictates that the opposing driveways shall be constructed directly opposite each other which will require the Ca'Nani driveway to be slightly relocated to the North of the proposed location to accomplish this. It is the recommendation of this office to realign the Ca'Nani winery driveway to improve turning movement access for both facilities. It is the applicant's responsibility to obtain the appropriate encroachment permits from CalTrans to accomplish this. If Caltrans does not support this recommendation or otherwise prohibits the relocation of the driveway the this condition may be removed without further analysis.
6. Access drive shall be a minimum of 18 feet wide with 2 feet of shoulder. Structural section shall be a minimum two inches of asphalt concrete surface over five inches of Class II Aggregate or equivalent (County Road and Street Standards-Common Drive, Page 9, Standard 12).
7. All driveway access to the public right of way must conform to the latest edition of the Napa County Road and Street Standards (Page 52, Detail P-2).
8. The applicant must obtain an encroachment permit for any work performed within the Napa County Right-of-Way.

## **SITE IMPROVEMENTS:**

9. All on site civil improvements including but not limited to the excavation, fill, general grading, drainage, curb, gutter, surface drainage, storm drainage, parking, and drive isles, shall be constructed according to plans prepared by a registered civil engineer, which will be reviewed and approved by this office prior to the commencement of any on site land preparation or construction. Plans shall be submitted with the building permit documents at the time of building permit application. A plan check fee will apply.

10. Proposed drainage for the development shall be shown on the improvement plans and shall avoid the diversion or concentration of stormwater runoff onto adjacent properties. Plan shall also include a hydraulic analysis for the drainage improvements indicating the path and changes of runoff.
11. Any grading, drainage and parking improvements approved by this Use Permit shall be constructed according to the latest "Napa County Road and Street Standards" and the 2007 California Building Code Appendix J and shall be reviewed and approved by this office prior to construction.
12. If excess material is generated that cannot be used onsite, the owner shall furnish to the County of Napa Public Works Department evidence that the owner has entered into agreements with the property owners of the site involved and has obtained the permits, licenses and clearances prior to commencing off-hauling operations.

#### **OTHER RECOMMENDATIONS:**

13. Prior to the issuance of any grading or building permit, or the signing of improvement plans, the permittee and County shall survey and document the condition of the nearest County road before construction begins, and then reevaluate conditions at the end of construction. Prior to Occupancy of any buildings or commencement of any use, the permittee shall be responsible for repair of any pavement degraded due to its construction vehicles.

#### **CONSTRUCTION STORMWATER REQUIREMENTS**

14. The property owner or his/her designee must understand all parts of these conditions and must maintain the construction site in compliance during all phases of construction.
15. Any construction activity that will result in disturbance of greater than one acre of total land area will require the permittee to obtain coverage in accordance with Napa County's General Permit for Discharges of Storm Water Associated with Construction Activity (Construction General Permit, 99-08-DWQ) issued by the Regional Water Quality Control Board (SRWQCB). To achieve this, the permittee shall file a Notice of Intent with the SRWQCB prior to any grading or construction activity. Construction activity subject to this permit includes but is not limited to clearing, grading and disturbances to the ground such as stockpiling, or excavation. The SWPPP relating to the project improvement plans shall be submitted with the building permit application. A plan check fee will apply.
16. Any construction activity that will result in disturbance of greater than 10,000 sq ft of total land area but less than one acre of total land area will require the permittee to prepare and maintain a Stormwater Quality Management Plan (SQMP) to be submitted with the building permit application. A plan check fee will apply.
17. All earth disturbing activities shall include measures to prevent erosion, sediment, and waste materials from leaving the site and entering waterways both during and after construction in conformance with the Napa County Stormwater Ordinance. Best Management Practices shall also

be implemented to minimize dust at all times. Grading on slopes greater than 5% between October 15 and April 1 requires an extension.

18. Implement effective erosion control measures, as appropriate, to protect exposed soils from being transported by rainfall, flowing water, or wind. Erosion control measures may include, but are not limited to: straw mulch, fiber mat blankets, bonded fiber matrix, soil compaction, and temporary and permanent vegetation.
19. Implement sediment control measures, as appropriate, to trap soil particles after they have been detached and moved by rain, flowing water, or wind. Examples of sediment control measures that may be used include, but are not limited to: fiber rolls, silt fence, check dams, and storm drain inlet protection.
20. Maintain a designated washout area to remove sediment and chemical pollutants that may be produced from cleaning tools and machinery. A washout area is a temporary wash basin sufficient in size to allow wash water to pond and allow the sedimentation and disposal of particles that have been rinsed off of project equipment. Pollutants include but are not limited to: paint, cement, stucco, etc.
21. Properly maintain all litter, dumps, or stockpiles in such a manner that they will not result in a contaminated discharge.
22. All hazardous materials stored and used on-site during construction that could cause water pollution (e.g. motor oil, cleaning chemicals, paints, concrete, etc.) shall be stored and used in a manner that will not cause pollution, with secondary containment provided. Such storage areas shall be regularly cleaned to remove litter and debris. Any spills shall be promptly cleaned up and appropriate authorities notified.
23. All entrances/exits of a project site shall be protected by a surface that will ensure any vehicles leaving the construction site will not track sediment onto any publicly maintained roadways.
24. The property owner shall inform all individuals, who will take part in the construction process, of these requirements.

#### **POST-CONSTRUCTION RUNOFF MANAGEMENT REQUIREMENTS**

25. Project must conform and incorporate all appropriate site design Best Management Practices as required by the Napa County manual for *Post-Construction Runoff Management Requirements* which is available at the Public Works office.
26. Prior to final occupancy the property owner must legally record an "implementation and maintenance agreement" approved by the Public Works department to ensure all post-construction structures on the property remain functional and operational for the indefinite duration of the project.

27. Crush pad areas must be covered, graded or otherwise controlled to preclude all runoff from entering the stormdrain system without human intervention.
28. Each year the entity responsible for maintenance of any installed post-construction stormwater facilities is required to complete an annual report that includes copies of completed inspection and maintenance checklists to document that maintenance activities were conducted during the previous year. The annual report shall be retained for a period of at least five years and made available upon request by the County.
29. Parking lots and other impervious areas shall be designed to drain through grassy swales, buffer strips, sand filters or other sediment control methods which will be approved by this Department.
30. If any discharge of concentrated surface waters is proposed into any "Waters of the State," the permittee shall consult with and secure any necessary permits from the State Regional Water Quality Control Board prior to the issuance of applicable construction permits.
31. Trash storage areas shall be paved with an impervious surface, designed not to allow run-on from adjoining areas, and screened or walled to prevent off-site transport of trash. Trash storage areas must contain a roof or awning to minimize direct precipitation or contain attached lids on all trash containers that exclude rain.

**Any changes in use may necessitate additional conditions for approval.**

If you have any questions regarding the above items please contact Drew Lander at 253-4351.