



A Tradition of Stewardship
A Commitment to Service

RECEIVED

OCT 29 2010

NAPA CO. CONSERVATION
DEVELOPMENT & PLANNING DEPT.

Environmental Management

1195 Third Street, Suite 101
Napa, CA 94559
www.co.napa.ca.us

Main: (707) 253-4471
Fax: (707) 253-4545

Steven Lederer
Director

MEMORANDUM

To: Napa County Planning Department, Chris Cahill, Planner	From: Kim Withrow, Senior Environmental Health Specialist <i>KW</i>
Date: October 27, 2010	Re: Application for Use Permit Located at Oakville Cross Rd., Oakville Assessor Parcel # 031-040-033 File # P08-00550-UP

The submitted application has been reviewed and this department recommends approval with the following conditions of approval:

1. The water supply and related components must comply with the California Safe Drinking Water Act and Related Laws. This will require plan review and approval prior to approval of building permits. Prior to occupancy, the owner must apply for and obtain an annual operating permit for the water system from this Department. The technical report must be completed by a licensed engineer with experience in designing water systems. The applicant must comply with all required monitoring and reporting.
2. Complete plans and specifications for the food preparation, service area(s), storage area(s) and the employee restrooms must be submitted for review and approval by this Department prior to issuance of any building permits for said areas. An annual food permit will be required.
3. Pursuant to Chapter 6.95 of the California Health and Safety Code, businesses that store hazardous materials above threshold planning quantities (55 gallons liquid, 200 cubic feet compressed gas, or 500 pounds of solids) shall obtain a permit and file an approved Hazardous Materials Business Plan with this Department within 30 days of said activities. If your business does not store hazardous materials above threshold planning quantities, submit the Business Activities Page indicating as such.
4. Any hazardous waste produced on site, including laboratory wastes, must be stored and disposed of in a manner consistent with Chapter 6.5, Division 20 of the California Health and Safety Code and with Title 22, Division 4.5 of the California Code of Regulations. Additionally, a Hazardous Waste Generator Permit must be obtained from this Department.

5. Plans for the proposed private sewage disposal system shall be designed by a licensed Civil Engineer or Registered Environmental Health Specialist and be accompanied by complete design criteria based upon local conditions. No building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system will be granted until such plans are approved by this Department.
6. A permit for the wastewater treatment and disposal system must be secured from this Department prior to approval of a building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system.
7. The use of the absorption field/drain field area shall be restricted to activities which will not contribute to compaction of the soil with consequent reduction in soil aeration. Activities which must be avoided in the area of the septic system include equipment storage, traffic, parking, pavement, livestock, and etc.
8. An annual alternative sewage treatment system monitoring permit must be obtained for the alternative sewage treatment system /private sewage disposal system prior to issuance of a final on the project. The septic system monitoring, as required by this permit, must be fully complied with.
9. All solid waste shall be stored and disposed of in a manner to prevent nuisances or health threats from insects, vectors and odors.
10. During the construction, demolition, or renovation period of the project the applicant must use the franchised garbage hauler for the service area in which they are located for all wastes generated during project development, unless applicant transports their own waste. If the applicant transports their own waste, they must use the appropriate landfill or solid waste transfer station for the service area in which the project is located.
11. Adequate area must be provided for collection of recyclables. The applicant must work with the franchised garbage hauler for the service area in which they are located, in order to determine the area and the access needed for the collection site. The garbage and recycling enclosure must meet the enclosure requirements provided during use permit process and be included on the building permit submittal.
12. All diatomaceous earth/bentonite must be disposed of in an approved manner. If the proposed septic system is an alternative sewage treatment system the plan submitted for review and approval must address bentonite disposal.