



## NAPA COUNTY

DEPARTMENT OF PUBLIC WORKS

1195 THIRD STREET • ROOM 201 • NAPA, CALIFORNIA 94559-3092  
PHONE 707-253-4351 • FAX 707-253-4627  
[www.co.napa.ca.us/PublicWorks/Default.htm](http://www.co.napa.ca.us/PublicWorks/Default.htm)

**RECEIVED**  
OCT - 2 2013  
Napa County Planning, Building  
& Environmental Services

ROBERT J. PETERSON  
Director of Public Works  
County Surveyor-County Engineer  
Road Commissioner

### WATER AVAILABILITY ANALYSIS

#### PHASE 1 STUDY

**Introduction:** As an applicant for a permit with Napa County, It has been determined that Chapter 13.15 of the Napa County Code is applicable to approval of your permit. One step of the permit process is to adequately evaluate the amount of water your project will use and the potential impact your application might have on the static groundwater levels within your neighborhood. The public works department requires that a Phase 1 Water Availability Analysis (WAA) be included with your application. The purpose of this form is to assist you in the preparation of this analysis. You may present the analysis in an alternative form so long as it substantially includes the information required below. Please include any calculations you may have to support your estimates.

The reason for the WAA is for you, the applicant, to inform us, to the best of your ability, what changes in water use will occur on your property as a result of an approval of your permit application. By examining the attached guidelines and filling in the blanks, you will provide the information we require to evaluate potential impacts to static water levels of neighboring wells.

#### **Step #1:**

Provide a map and site plan of your parcel(s). The map should be an 8-1/2"x11" reproduction of a USGS quad sheet (1:24,000 scale) with your parcel outlined on the map. Include on the map the nearest neighboring well. The site plan should be an 8-1/2"x11" site plan of your parcel(s) with the locations of all structures, gardens, vineyards, etc in which well water will be used. If more than one water source is available, indicate the interconnecting piping from the subject well to the areas of use. Attach these two sheets to your application. If multiple parcels are involved, clearly show the parcels from which the fair share calculation will be based and properly identify the assessors parcel numbers for these parcels. Identify all existing or proposed wells.

**Step #2:** Determine total parcel acreage and water allotment factor. If your project spans multiple parcels, please fill a separate form for each parcel.

Determine the allowable water allotment for your parcels: APN 047-070-007

#### **Parcel Location Factors**

The allowable allotment of water is based on the location of your parcel.



There are 3 different location classifications. Valley floor areas include all locations that are within the Napa Valley, Pope Valley and Carneros Region, except for areas specified as groundwater deficient areas. Groundwater deficient areas are areas that have been determined by the public works department as having a history of problems with groundwater. All other areas are classified as Mountain Areas. Please circle your location classification below (Public Works can assist you in determining your classification if necessary):

Valley Floor 1.0 acre feet per acre per year  
 Mountain Areas 0.5 acre feet per acre per year  
 MST Groundwater Deficient Area 0.3 acre feet per acre per year

Assessors Number(s)	Parcel	Parcel Size (A)	Parcel Factor (B)	Location	Allowable Water Allotment (A) X (B)
047-070-007		137.36	1.0		137.0 AF/ Year

### Step #3:

Using the guidelines in Attachment A, tabulate the existing and projected future water usage on the parcel(s) in acre-feet per year (af/yr). Transfer the information from the guidelines to the table below.

#### EXISTING USE:

Residential 0.5 af/yr  
 Vineyard 20.2\* af/yr  
 Winery PW\*\* 9.29 af/yr  
 Winery DW\*\*\* & Landscaping 2.16 af/yr

#### PROPOSED USE:

Residential 0.5 af/yr  
 Vineyard 20.2\* af/yr  
 Winery PW\*\* 9.29 af/yr  
 Winery DW\*\*\* & Landscape 2.16 af/yr

Other Usage (List Separately):

\_\_\_\_ af/yr  
 \_\_\_\_ af/yr  
 \_\_\_\_ af/yr

Other Usage (List Separately):

\_\_\_\_ af/yr  
 \_\_\_\_ af/yr  
 \_\_\_\_ af/yr

TOTAL: 32.15 af/yr  
 TOTAL: 10,475,145 gallons\*\*\*\*

TOTAL: 32.15 af/yr  
 TOTAL: 10,475,145 gallons\*\*\*\*

\*Water use for vineyards should be no lower than 0.2 AF—unless irrigation records are available that show otherwise. ***This low use of 0.2 AF is appropriate in this case due to the reuse of winery process wastewater (PW) as well as the rainfall catchment in the irrigation reservoir.***

\*\*Process Wastewater

\*\*\*Domestic Wastewater

\*\*\*\*To determine your existing and proposed total water use in gallons, multiply the totals (in acre-feet) by 325,821 gal/AF.

Is the proposed use less than the existing usage ☐ Yes ☐ No ☒ Equal



#### **Step #4:**

Provide any other information that may be significant to this analysis. For example, any calculations supporting your estimates, well test information including draw down over time, historical water data, visual observations of water levels, well drilling information, changes in neighboring land uses, the usage of other water sources such as city water or reservoirs, the timing of the development, etc. Use additional sheets if necessary.

*The projected water usage totals listed in Step #3 above are based on one primary residence (with only two residents total) on the parcel, 101 planted acres of vineyard (which are irrigated by an irrigation reservoir that utilizes rain water and reclaimed winery process wastewater), and an existing winery Use Permit for 180,000 cases or 432,000 gallons of annual wine production.*

**Conclusion:** Congratulations! Just sign the form and you are done! Public works staff will now compare your projected future water usage with a threshold of use as determined for your parcel(s) size, location, topography, rainfall, soil types, historical water data for your area, and other hydrogeologic information. They will use the above information to evaluate if your proposed project will have a detrimental effect on groundwater levels and/or neighboring well levels. Should that evaluation result in a determination that your project may adversely impact neighboring water levels, a phase two water analysis may be required. You will be advised of such a decision.

Signature:  Date: Oct. 1, 2013 Phone: 707-824-0266  
Tamara Martin, REHS

#### **Attachment A: Estimated Water Use Guidelines**

### Typical Water Use Guidelines:

Primary Residence	0.5 to 0.75 acre-feet per year (includes some landscaping)
Secondary Residence	0.20 to 0.30 acre-feet per year
Farm Labor Dwelling	0.06 to 0.10 acre-feet per person per year

### Non-Residential Guidelines:

#### Agricultural:

Vineyards	
Irrigation only	0.2 to 0.5 acre-feet per acre per year
Heat Protection	0.25 acre feet per acre per year
Frost Protection	0.25 acre feet per acre per year
Farm Labor Dwelling	0.06 to 0.10 acre-feet per person per year
Irrigated Pasture	4.0 acre-feet per acre per year
Orchards	4.0 acre-feet per acre per year
Livestock (sheep or cows)	0.01 acre-feet per acre per year

#### Winery:

Process Water	2.15 acre-feet per 100,000 gal. of wine
Domestic and Landscaping	0.50 acre-feet per 100,000 gal. of wine

#### Industrial:

Food Processing	31.0 acre-feet per employee per year
Printing/Publishing	0.60 acre-feet per employee per year

#### Commercial:

Office Space	0.01 acre-feet per employee per year
Warehouse	0.05 acre-feet per employee per year