

“B”

**Recommended Conditions of Approval
and Final Agency Approval Memos**

**PLANNING COMMISSION HEARING – APRIL 18, 2018
RECOMMENDED CONDITIONS OF APPROVAL**

**Dry Creek/Mount Veeder Winery
Use Permit No. P17-00343-UP and Variance No. P17-00345-VAR
Intersection of Dry Creek Road and Mount Veeder Road, Oakville, CA
APN 027-310-039**

This permit encompasses and shall be limited to the project commonly known as **Dry Creek/Mount Veeder Winery**, located at **the intersection of Dry Creek Road and Mount Veeder Road**. Part I encompasses the Project Scope and general conditions pertaining to statutory and local code references, project monitoring, and the process for any future changes or activities. Part II encompasses the ongoing conditions relevant to the operation of the project. Part III encompasses the conditions relevant to construction and the prerequisites for a Final Certificate of Occupancy. It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved.

Where conditions are not applicable or relevant to this project, they shall be noted as “Reserved” and therefore have been removed.

When modifying a legally established entitlement related to this project, these conditions are not intended to be retroactive or to have any effect on existing vested rights except where specifically indicated.

PART I

1.0 PROJECT SCOPE

The permit encompasses and shall be limited to:

- 1.1 Approval of a Variance to allow the covered crush pad and winery building to encroach 216 feet and 196 feet, respectively, into the required 300 foot setback from Mount Veeder Road.
- 1.2 Approval of a Use Permit for a 30,000 gallon per year winery to allow the following:
 - a. Construction of a 2,400 square foot winery building (includes a 150 square foot tasting room); a 17,220 square foot cave (includes 15,890 square feet of barrel storage, 1,176 square feet for equipment/utility space, and 154 square feet of accessory space); 800 square foot covered crush pad; 2,942 square foot covered outdoor work area; and a 619 square foot owner/winemaker residence with 519 square foot covered patio;
 - b. Visitation, tours and tasting, and a marketing plan as set forth in Conditions of Approval (COAs) Nos. 4.1 through 4.3 below;
 - c. On-premises consumption of wine as set forth in COA No. 4.4 below;

- d. Daily hours of operation for winery production activities shall be limited to 8:00 AM to 6:00 PM (except during crush) and visitation activities shall be limited to 10 AM to 4 PM, seven days a week;
- e. Maximum number of employees; four (4) full time employees;
- f. Number of parking spaces; eight (8) parking spaces (seven (7) standard spaces and one ADA space);
- g. Installation of a waste water system;
- h. Construction of one new driveway to access Mount Veeder Road;
- i. Installation of landscaping; and
- j. Installation of one 20,000 gallon water storage tank (12,000 gallons for fire protection and 8,000 gallons for domestic use), use of one existing well, and demolition of one existing well.

The winery shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code (the County Code). It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved. Any expansion or change in winery use or alternative locations for fire suppression or other types of water tanks shall be approved in accordance with the County Code and may be subject to the permit modification process.

2.0 STATUTORY AND CODE SECTION REFERENCES

All references to statutes and code sections shall refer to their successor as those sections or statutes may be subsequently amended from time to time.

3.0 MONITORING COSTS

All staff costs associated with monitoring compliance with these conditions, previous permit conditions, and project revisions shall be borne by the permittee and/or property owner. Costs associated with conditions of approval and mitigation measures that require monitoring, including investigation of complaints, other than those costs related to investigation of complaints of non-compliance that are determined to be unfounded, shall be charged to the property owner or permittee. Costs shall be as established by resolution of the Board of Supervisors in accordance with the hourly consulting rate established at the time of the monitoring and shall include maintenance of a \$500 deposit for construction compliance monitoring that shall be retained until issuance of a Final Certificate of Occupancy. Violations of conditions of approval or mitigation measures caused by the permittee's contractors, employees, and/or guests are the responsibility of the permittee.

The Planning Commission may implement an audit program if compliance deficiencies are noted. If evidence of a compliance deficiency is found to exist by the Planning Commission at some time in the future, the Planning Commission may institute the program at the applicant's expense (including requiring a deposit of funds in an amount determined by the Commission) as needed until compliance assurance is achieved. The Planning Commission may also use the data, if so warranted, to commence revocation proceedings in accordance with the County Code.

PART II

4.0 OPERATIONAL CHARACTERISTICS OF THE PROJECT

Permittee shall comply with the following during operation of the winery:

4.1 GENERAL PROVISIONS

Consistent with the County Code, tours and tastings and marketing may occur at a winery only where such activities are accessory and “clearly incidental, related, and subordinate to the primary operation of the winery as a production facility.”

Tours and tastings (defined below) may include food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery and is incidental to the tasting of wine. Food service may not involve menu options and meal service such that the winery functions as a café or restaurant.

Retail sales of wine shall be permitted as set forth in the County Code.

4.2 TOURS AND TASTINGS/VISITATION

Tours and tastings shall be by appointment only and shall be limited to the following:

- a. Frequency: seven days per week, Monday through Sunday
- b. Maximum number of persons per day: 10
- c. Maximum number of persons per week: 70
- d. Hours of visitation: 10:00 am to 4:00 pm

“Tours and tastings” means tours of the winery and/or tastings of wine, where such tours and tastings are limited to persons who have made unsolicited prior appointments for tours or tastings. To the maximum extent feasible, scheduling of visitors shall not occur during peak travel times 3:00 PM to 6:00 PM.

A log book (or similar record) shall be maintained to document the number of visitors to the winery (for either tours and tastings or marketing events), and the dates of the visits. This record of visitors shall be made available to the Planning, Building and Environmental Services (PBES) Department upon request.

4.3 MARKETING

Marketing events shall be limited to the following:

- a. **Type 1**
 1. Frequency: 10 times per year
 2. Maximum number of persons: 30
 3. Time of Day: 11:00 am to 10:00 pm
- b. **Type 2**

1. Frequency: 1 time per year
 2. Maximum number of persons: 100
 3. Time of Day: 11:00 am to 10:00 pm
- c. Marketing events of more than 30 persons shall not begin nor end during the hours of 3:00 PM to 6:00 PM.
- d. Tours and tastings authorized in COA No. 4.2 shall not occur when 100 person marketing events are scheduled.
- e. All food to be catered.

"Marketing of wine" means any activity of a winery which is conducted at the winery on a prearranged basis for the education and development of customers and potential customers with respect to wine which can be sold at the winery on a retail basis pursuant to the County Code. Marketing of wine may include cultural and social events directly related to the education and development of customers and potential customers provided such events are clearly incidental, related and subordinate to the primary use of the winery. Marketing of wine may include food service, including food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery.

Business events are similar to cultural and social events, in that they will only be considered as "marketing of wine" if they are directly related to the education and development of customers and potential customers of the winery and are part of a marketing plan approved as part of the winery's Use Permit. To be considered directly related to the education and development of customers or potential customers of the winery, business events must be conducted at no charge except to the extent of cost recovery, and any business content unrelated to wine must be limited.

Careful consideration shall be given to the intent of the event, the proportion of the business event's non-wine-related content, and the intensity of the overall marketing plan (County Code).

All marketing event activity, excluding quiet clean-up, shall cease by 10:00 pm. If any event is held which will exceed the available on-site parking, the permittee shall prepare an event-specific parking plan which may include, but not be limited to, valet service or off-site parking and shuttle service to the winery.

Auction Napa Valley (ANV) events need not be included in a participating winery's marketing plan because they are covered by ANV's Category 5 Temporary Permit. The winery may utilize any ANV event authorized in this permit for another charitable event of similar size.

4.4 ON-PREMISES CONSUMPTION

In accordance with State law and the PBES Director's July 17, 2008 memo, "Assembly Bill 2004 (Evans) & the Sale of Wine for Consumption On-Premises,"

on-premises consumption of wine produced on-site and purchased from the winery may occur solely in the 519 square foot covered patio. Any and all visitation associated with on-premises consumption shall be subject to the maximum per person weekday and weekend daily tours and tastings visitation limitation and/or applicable limitations of permittee's marketing plan set forth in COA Nos.4.2 and 4.3 above.

4.5 RESIDENCE OR NON-WINERY STRUCTURES

Unless specifically authorized by this permit or a previously approved permit, the proposed owner/winemaker residence shall not be used for commercial purposes or in conjunction with the operation and/or visitation/marketing program for the winery. If the residence is rented, it shall only be rented for periods of 30 days or more, pursuant to the County Code.

4.6 GRAPE SOURCE

At least 75% of the grapes used to make the winery's still wine or the still wine used by the winery to make sparkling wine shall be grown within Napa County. The permittee shall keep records of annual production documenting the source of grapes to verify that 75% of the annual production is from Napa County grapes. The report shall recognize the Agriculture Commission's format for County of origin of grapes and juice used in the Winery Production Process. The report shall be provided to the PBES Department upon request, but shall be considered proprietary information and not available to the public.

4.7 COMPLIANCE REVIEW

Permittee shall obtain and maintain all permits (use permits and modifications) and licenses from the California Department of Alcoholic Beverage Control (ABC) and United States Tax and Trade Bureau (TTB), and California Department of Food and Agriculture (CDFA) Grape Crush Inquiry data, all of which are required to produce and sell wine. In the event the required ABC and/or TTB permits and/or licenses are suspended or revoked, permittee shall cease marketing events and tours and tastings until such time as those ABC and/or TTB permits and licenses are reinstated.

Visitation log books, visitor reports, custom crush client records, and any additional documentation determined by Staff to be necessary to evaluate compliance may be requested by the County for any code compliance. The permittee (and their successors) shall be required to participate fully in the winery code compliance review process.

4.8 RENTAL/LEASING

No winery facilities, or portions thereof, including, without limitation, any kitchens, barrel storage areas, or warehousing space, shall be rented, leased, or used by entities other than persons producing and/or storing wine at the winery, such as alternating proprietors and custom producers, except as may be specifically authorized in this Permit or pursuant to the Temporary Events Ordinance (County Code Chapter 5.36).

4.9 GROUND WATER MANAGEMENT - WELLS

This condition is implemented jointly by the Public Works and PBES Departments:

The permittee shall be required (at the permittee's expense) to record well monitoring data (specifically, static water level no less than quarterly, and the volume of water no less than monthly). Such data will be provided to the County, if the PBES Director determines that substantial evidence¹ indicates that water usage at the winery is affecting, or would potentially affect, groundwater supplies or nearby wells. If data indicates the need for additional monitoring, and if the applicant is unable to secure monitoring access to neighboring wells, onsite monitoring wells may need to be established to gauge potential impacts on the groundwater resource utilized for the project. Water usage shall be minimized by use of best available control technology and best water management conservation practices.

In order to support the County's groundwater monitoring program, well monitoring data as discussed above will be provided to the County if the Director of Public Works determines that such data could be useful in supporting the County's groundwater monitoring program. The project well will be made available for inclusion in the groundwater monitoring network if the Director of Public Works determines that the well could be useful in supporting the program.

In the event that changed circumstances or significant new information provide substantial evidence¹ that the groundwater system referenced in the Use Permit would significantly affect the groundwater basin, the PBES Director shall be authorized to recommend additional reasonable conditions on the permittee, or revocation of this permit, as necessary to meet the requirements of the County Code and to protect public health, safety, and welfare.

4.10 AMPLIFIED MUSIC

There shall be no amplified sound system or amplified music utilized outside of approved, enclosed, winery buildings.

4.11 TRAFFIC

To the maximum extent feasible, scheduling of reoccurring vehicle trips to and from the site for employees and deliveries shall not occur during peak travel times (3:00 PM to 6:00 PM weekdays; 3:00 PM to 6:00 PM Saturdays and Sundays). All road improvements on private property required per Engineering Services shall be maintained in good working condition and in accordance with the Napa County Roads and Streets Standards.

¹ Substantial evidence is defined by case law as evidence that is of ponderable legal significance, reasonable in nature, credible and of solid value. The following constitute substantial evidence: facts, reasonable assumptions predicated on facts; and expert opinions supported by facts. Argument, speculation, unsubstantiated opinion or narrative, or clearly inaccurate or erroneous information do not constitute substantial evidence.

4.12 PARKING

The location of visitor parking and truck loading zone areas shall be identified along with proposed circulation and traffic control signage (if any).

Parking shall be limited to approved parking spaces only and shall not occur along access or public roads or in other locations except during harvest activities and approved marketing events. In no case shall parking impede emergency vehicle access or public roads.

4.13 BUILDING DIVISION – USE OR OCCUPANCY CHANGES

Please contact the Building Division with any questions regarding the following:

In accordance with the California Building Code (CBC), no change shall be made in the use of occupancy of an existing building unless the building is made to comply with the requirements of the current CBC for a new building.

4.14 FIRE DEPARTMENT – TEMPORARY STRUCTURES

Please contact the Fire Department with any questions regarding the following:

The permittee and/or designee shall obtain a tent permit from the Fire Department for any temporary structures utilized for authorized marketing events allowed per COA No. 4.3 above.

4.15 NAPA COUNTY MOSQUITO ABATEMENT PROGRAM **[RESERVED]**

4.16 GENERAL PROPERTY MAINTENANCE – LIGHTING, LANDSCAPING, PAINTING, OUTDOOR EQUIPMENT STORAGE, AND TRASH ENCLOSURE AREAS

- a. All lighting shall be permanently maintained in accordance with the lighting and building plans approved by the County. Lighting utilized during harvest activities is exempt from this requirement.
- b. All landscaping and outdoor screening, storage, and utility structures shall be permanently maintained in accordance with the landscaping and building plans approved by the County. No stored items shall exceed the height of the screening. Exterior winery equipment shall be maintained so as to not create a noise disturbance or exceed noise thresholds in the County Code.
- c. The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division prior to any change in paint colors that differs from the approved building permit. Highly reflective surfaces are prohibited.
- d. Designated trash enclosure areas shall be made available and properly maintained for intended use.

4.17 NO TEMPORARY SIGNS

Temporary off-site signage, such as “A-Frame” signs, is prohibited.

4.18 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – OPERATIONAL CONDITIONS

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies’ requirements. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division operational conditions as stated in their Memorandum dated March 16, 2018.
- b. Environmental Health Division operational conditions as stated in their Memorandum dated April 6, 2018.
- c. Building Division operational conditions as stated in their Memorandum dated October 5, 2017.
- d. Department of Public Works operational conditions as stated in their Memorandum dated January 31, 2018.
- e. Fire Department operational conditions as stated in their Inter-Office Memo dated October 20, 2017.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify this permit.

4.19 OPERATIONAL MITIGATION MEASURES

The permittee shall comply with the following operational mitigation measures identified in the adopted Initial Study/Mitigated Negative Declaration and Project Revision Statement/Mitigation Monitoring and Reporting Program prepared for the project:

- a. **MM TRANS-1:** Landscaping at the project driveway shall be maintained to not interfere with sight lines required for safe stopping distance on public right-of-way. No items that are wider than 18 inches can be taller than 30 inches other than street trees and traffic devices. Street trees should be deciduous and have branches lower than four feet in height removed once the tree is established.

Method of Monitoring: The final landscape plan shall reflect the implementation of these standards prior to issuance of a building permit.

Responsible Agency: PBES

4.20 OTHER CONDITIONS APPLICABLE TO THE OPERATIONAL ASPECTS OF THE PROJECT **[RESERVED]**

4.21 PREVIOUS CONDITIONS **[RESERVED]**

PART III

5.0 PREREQUISITE FOR ISSUANCE OF PERMITS

5.1 PAYMENT OF FEES

No building, grading or sewage disposal permits shall be issued or other permits authorized until all accrued planning permit processing fees have been paid in full. This includes all fees associated with plan check and building inspections, associated development impact fees established by County Ordinance or Resolution, and the Napa County Affordable Housing Mitigation Fee in accordance with County Code.

6.0 GRADING/DEMOLITION/ENVIRONMENTAL/BUILDING PERMIT/OTHER PERMIT PREREQUISITES

Permittee shall comply with the following with the submittal of a grading, demolition, environmental, building and/or other applicable permit applications.

6.1 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – PLAN REVIEW, CONSTRUCTION AND PREOCCUPANCY CONDITIONS

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies' requirements. The permittee shall comply with all applicable building codes, zoning standards, and requirements of County Divisions, Departments and Agencies at the time of submittal and may be subject to change. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated March 16, 2018.
- b. Environmental Health Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated April 6, 2018.
- c. Building Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated October 5, 2017.
- d. Department of Public Works plan review/construction/ preoccupancy conditions as stated in their Memorandum dated January 31, 2018.
- e. Fire Department plan review/construction/ preoccupancy conditions as stated in their Inter-Office Memo dated October 20, 2017.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify the permit.

6.2 BUILDING DIVISION – GENERAL CONDITIONS

- a. A building permit shall be obtained for all construction occurring on the site not otherwise exempt by the California Building Code (CBC) or any State or local amendment adopted thereto.
- b. If there are any existing structures and/or buildings on the property that will need to be removed to accommodate construction activities, a separate demolition permit shall be required from the Building Division prior to removal. The permittee shall provide a “J” number from the Bay Area Air Quality Management District (BAAQMD) at the time the permittee applies for a demolition permit if applicable.
- c. All areas of newly designed and newly constructed buildings, facilities and on-site improvements must comply with the CBC accessibility requirements, as well as, American with Disability Act requirements when applicable. When alterations or additions are made to existing buildings or facilities, an accessible path of travel to the specific area of alteration or addition shall be provided as required per the CBC.

6.3 LIGHTING – PLAN SUBMITTAL

- a. Two (2) copies of a detailed lighting plan showing the location and specifications for all lighting fixtures to be installed on the property shall be submitted for Planning Division review and approval. All lighting shall comply with the CBC.
- b. All exterior lighting, including landscape lighting, shall be shielded and directed downward, shall be located as low to the ground as possible, shall be the minimum necessary for security, safety, or operations; on timers; and shall incorporate the use of motion detection sensors to the greatest extent practical. All lighting shall be shielded or placed such that it does not shine directly on adjacent properties or impact vehicles on adjacent streets. No flood-lighting or sodium lighting of the building is permitted, including architectural highlighting and spotting. Low-level lighting shall be utilized in parking areas as opposed to elevated high-intensity light standards. Lighting utilized during harvest activities is exempt from this requirement.

6.4 LANDSCAPING – PLAN SUBMITTAL

- a. Two (2) copies of a detailed final landscaping and irrigation plan, including parking details, shall be submitted with the building permit application package for the Planning Division’s review and approval prior to the issuance of any building permit associated with this Use Permit.

The plan shall be prepared pursuant to the County's Water Efficient Landscape Ordinance (Chapter 18.118 of the County Code) requirements in effect at the time of building permit application submittal, as applicable, and shall indicate the names and locations of all plant materials to be used along with their method of maintenance.

- b. Plant materials shall be purchased locally when practical, and to the greatest extent possible, the plant materials shall be the same native plants found in Napa County. The Agricultural Commissioner's office shall be notified of all impending deliveries of live plants with points of origin outside of Napa County.
- c. No trees greater than 6" diameter at breast height shall be removed, except for those identified on the submitted site plan. Any Oak trees removed as a result of the project shall be replaced at a 2:1 ratio and shown on the landscaping plans for the Planning Division's review and approval. Trees to be retained shall be protected during construction by fencing securely installed at the outer most dripline of the tree or trees. Such fencing shall be maintained throughout the duration of the work undertaken in connection with the winery development/construction. In no case shall construction material, debris or vehicles be stored in the fenced tree protection area.
- d. Evergreen screening shall be installed between the industrial portions of the operation (e.g. tanks, crushing area, parking area, etc.) and any off-site residence from which these areas can be viewed.

6.5 COLORS

The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division in conjunction with building permit review and/or prior to painting the building. Highly reflective surfaces are prohibited.

6.6 OUTDOOR STORAGE/SCREENING/UTILITIES

- a. Details of outdoor storage areas and structures shall be included on the building and landscape plans. All outdoor storage of winery equipment shall be screened from the view of residences of adjacent properties by a visual barrier consisting of fencing or dense landscaping. No stored item shall exceed the height of the screening. Water and fuel tanks, and similar structures, shall be screened to the extent practical so as to not be visible from public roads and adjacent parcels.
- b. New utility lines required for this project that are visible from any designated scenic transportation route (see Community Character Element of the General Plan and the County Code) shall be placed underground or in an equivalent manner be made virtually invisible from the subject roadway.

- c. Exterior winery equipment shall be located, enclosed or muffled so as not to exceed noise thresholds in the County Code.

6.7 TRASH ENCLOSURES

Adequate area must be provided for collection and loading of garbage and recyclables generated by the project. The applicant must work with the franchised garbage hauler for the service area in which they are located, in order to determine the area and the pedestrian and vehicle access needed for the collection site. The garbage and recycling enclosure shall meet the minimum enclosure requirements established by staff and the franchised hauler, which shall be included in the building permit submittal.

6.8 ADDRESSING

All project site addresses shall be determined by the PBES Director, and be reviewed and approved by the United States Post Office. The PBES Director reserves the right to issue or re-issue an appropriate situs address at the time of issuance of any building permit to ensure proper identification and sequencing of numbers. For multi-tenant or multiple structure projects, this includes building permits for later building modifications or tenant improvements.

6.9 HISTORIC RESOURCES **[RESERVED]**

6.10 DEMOLITION ACTIVITIES **[RESERVED]**

6.11 VIEWSHED – EXECUTION OF USE RESTRICTION **[RESERVED]**

6.12 PERMIT PREREQUISITE MITIGATION MEASURES

The permittee shall comply with the following permit prerequisite mitigation measures identified in the adopted Initial Study/Mitigated Negative Declaration and Project Revision Statement/Mitigation Monitoring and Reporting Program prepared for the project:

- a. **MM BIO-1:** In order to avoid disruption of wildlife movement along the Dry Creek riparian corridor, a wildlife movement and riparian corridor buffer shown as a red polygon in Figure 2 in the *Biological Resource Assessment with Botanical and Bat Habitat Surveys, Woodland Assessment, and Delineation of Waters of the U.S. for the Dry Creek-Mt. Veeder Project APN 027-310-039 Napa County, CA* prepared by Northwest Biosurvey shall be implemented. The westward edge of this buffer shall be defined by a low, deer-passable fence or wall to prevent vehicle movement or storage within the buffer and to establish a sense of usable space for wildlife. Deer fencing shall be restricted to the development areas and shall not extend along linear features such as roadways or property lines.

Method of Monitoring: The wildlife movement and riparian corridor buffer shall be shown on the site plan prior to the issuance of a grading permit or building permit.

Responsible Agency: PBES

- b. **MM BIO-2:** If vegetation clearing or other land disturbance within 100 feet of Douglas Fir or California black oak forest is proposed during the bird breeding season (February 15 through August 31), the work shall be preceded by a survey for Lewis' woodpecker and other migratory passerines (perching birds) by a qualified biologist within 14 days prior to the beginning of work. In the event that nesting birds are found during the survey, construction buffers shall be established by the biologist in cooperation with the California Department of Fish and Wildlife. These buffers shall remain in place until offspring have fledged or after August 31.

Method of Monitoring: If vegetation clearing or other land disturbance within 100 feet of Douglas Fir or California black oak forest is proposed during the bird breeding season (February 15 through August 31), the Lewis' woodpecker and other migratory passerines (perching birds) survey shall be submitted to Planning Division staff prior to issuance of the grading permit.

Responsible Agency: PBES

- c. **MM BIO-3:** Prior to commencement of vegetation removal and earth-disturbing activities during nesting season from February 1 to July 9, a qualified wildlife biologist shall conduct preconstruction surveys for Northern Spotted Owls within 500-feet of earthmoving activities. The preconstruction survey shall be conducted no more than 14 days prior to vegetation removal and ground disturbing activities are to commence. A copy of the survey shall be provided to the County Planning Division and the Department of Fish and Wildlife (DFW) prior to commencement of work. If Northern Spotted Owls are found during preconstruction survey, a 500-foot no-disturbance buffer shall be created around active owl sites. These buffer zones may be modified in coordination with DFW based on existing conditions at the project site. Buffer zones shall be incorporated into the project plans and maintained for the duration of the project. If a 15 day or greater lapse of project-related work occurs, another pre-construction survey and consultation with DFW shall be required before project work can be reinitiated.

No surveys shall be required if construction activity occurs outside of the nesting season from February 1 to July 9.

Method of Monitoring: If construction activity is to occur during the nesting season from February 1 to July 9, the pre-construction survey prepared by a qualified wildlife biologist shall be submitted to Planning Division staff prior to issuance of the grading permit.

Responsible Agency: PBES

- d. **MM BIO-4:** If trees are to be removed outside of the dates listed below, any tree to be removed that is suitable for use by bats shall be surveyed for signs of bats. This survey shall occur no earlier than 14 days prior to tree removal. Suitable trees include those with hollows and/or shedding bark. If pallid bats, or other bats with sensitive regulatory status, are discovered during the surveys, a buffer of 50 feet shall be established depending on the recommendations of the surveying biologist. Removal of these roost trees shall be restricted to between September 15 and October 15, when young of the year are capable of flying, or between February 15 and April 1 to avoid hibernating bats and prior to formation of maternity sites.

Method of Monitoring: If trees are to be removed outside of the dates listed above, the pre-construction bat survey shall be submitted to Planning Division staff prior to issuance of the grading permit.

Responsible Agency: PBES

- e. **MM BIO-5:** If any placement of fill within the tributary marked as channel "B" in the *Biological Resource Assessment with Botanical and Bat Habitat Surveys, Woodland Assessment, and Delineation of Waters of the U.S. for the Dry Creek-Mt. Veeder Project APN 027-310-039 Napa County, CA* is proposed, consultation and permitting must be obtained from the U.S Army Corps of Engineers, Regional Water Quality Control Board, and California Department of Fish and Wildlife prior to and during the construction.

Method of Monitoring: Proof of the required permits (404 permit by the U.S. Corps of Engineers, 401 Water Quality Certification from the Regional Water Quality Control Board, and 1604 Stream Alteration Agreement from the California Department of Fish and Wildlife) and consultation for any placement of fill within the tributary marked as channel "B" in the *Biological Resource Assessment with Botanical and Bat Habitat Surveys, Woodland Assessment, and Delineation of Waters of the U.S. for the Dry Creek-Mt. Veeder Project APN 027-310-039 Napa County, CA* from the agencies identified above shall be submitted to Planning Division staff prior to the issuance of a grading permit.

Responsible Agency: PBES

- f. **MM GEO-1:** Prior to building permit submittal, a subsurface geological exploration of the proposed winery building and cave site shall be conducted by a qualified geologist and shall include a geologic hazard report containing the information and technical recommendations required under Napa County Code section 15.08.050.

Method of Monitoring: The grading and building plans shall reflect the implementation of the preliminary geotechnical report recommendations prior to issuance of a grading and building permit.

Responsible Agency: PBES

- g. **MM NOI-1:** Prior to the issuance of any building permits to implement this use permit, the permittee shall submit an operation plan for the bottling and outdoor work area which shall require the bottling truck to be oriented such that open trailer doors, bottling lines, glass and container staging areas are located in the east and south sides of the truck. A sound curtain shall be utilized on the northern and eastern portions of the work area and all work shall occur on the approved outdoor work area and crush pad. The operations plan shall be prepared under the direction of a qualified acoustics professional, and shall be subject to review and approval of the Planning Division.

Method of Monitoring: County Planning Division Staff shall review and approve the operations plan prior to issuance of building permit plans for the project. Planning Division staff will inspect the facility prior to final occupancy. County Code Enforcement Staff through winery use permit compliance audits, such that future use of the operations plan will be monitored. Code Enforcement staff will respond to any noise complaints.

Responsible Agency: PBES

- h. **MM NOI-2:** Prior to the issuance of any building permits to implement this use permit, the permittee shall submit plans for a temporary sound curtain to be placed in the vicinity of the outdoor work area/crush pad which shall be used when outdoor events of 100 guests occur. The sound curtain shall be designed by a qualified acoustics professional, shall be in substantial conformance with the recommendations put forth in the RGD Acoustics study incorporated herein, and shall result in noise levels meeting the current standards of the County for exterior and interior noise exposure. Final design of the sound curtain is subject to review and approval by the Planning Division.

Method of Monitoring: County Planning Division Staff shall review and approve the sound curtain design prior to issuance of building permit plans for the project. Planning Division staff will inspect the facility prior to final occupancy. County Code Enforcement Staff through winery use permit compliance audits, such that future use of the sound curtain for outdoor events will be monitored. Code Enforcement staff will respond to any noise complaints.

Responsible Agency: PBES

- i. **MM TRI-1:** Prior to commencement of construction of project improvements at the project site, the permittee shall coordinate with a representative of Yocha Dehe Wintun Nation. Pre-construction coordination shall include a training of construction field crews, by a tribal representative of the potential for presence of Native American resources on the property, the potential types of resources that could be found on-site, and the procedures to follow in the event of discovery of such resources.

Method of Monitoring: Concurrently with submittal of the grading application for project improvements to Engineering and Building staff of PBES, the permittee shall submit confirmation of submittal of the grading plans to the tribal representative previously identified. If the permittee neglects to submit such confirmation to PBES, then Planning staff of PBES will convey a copy of the plans to the tribal representative upon receipt of the grading permit application.

Responsible Agency: PBES

6.13 PARCEL CHANGE REQUIREMENTS **[RESERVED]**

6.14 FINAL MAPS **[RESERVED]**

6.15 OTHER CONDITIONS APPLICABLE TO THE PROJECT PERMITTING PROCESS

- a. Prior to building permit issuance, eight parking spaces, (seven standard and one ADA space) shall be shown on the site plan.

7.0 PROJECT CONSTRUCTION

Permittee shall comply with the following during project construction:

7.1 SITE IMPROVEMENTS

Please contact Engineering Services with any questions regarding the following.

- a. **GRADING AND SPOILS**
All grading and spoils generated by construction of the project facilities shall be managed per Engineering Services direction. Alternative locations for spoils are permitted, subject to review and approval by the PBES Director, when such alternative locations do not change the overall concept, and do not conflict with any environmental mitigation measures or conditions of approval.
- b. **DUST CONTROL**
Water and/or dust palliatives shall be applied in sufficient quantities during grading and other ground disturbing activities on-site to minimize the amount of dust produced. Outdoor construction activities shall not occur when average wind speeds exceed 20 mph.

c. AIR QUALITY

During all construction activities the permittee shall comply with the most current version of BAAQMD Basic Construction Best Management Practices including but not limited to the following, as applicable:

1. Post a publicly visible sign with the telephone number and person to contact at the lead agency regarding dust complaints. The BAAQMD's phone number shall also be visible.
2. Water all exposed surfaces (e.g., parking areas, staging areas, soil piles, grading areas, and unpaved access roads) two times per day.
3. Cover all haul trucks transporting soil, sand, or other loose material off-site.
4. Remove all visible mud or dirt traced onto adjacent public roads by using wet power vacuum street sweepers at least once per day. The use of dry power sweeping is prohibited.
5. All vehicle speeds on unpaved roads shall be limited to 15 mph.
6. All roadways, driveways, and sidewalks to be paved shall be completed as soon as possible. Building pads shall be laid as soon as possible after grading unless seeding or soil binders are used.
7. Idling times shall be minimized either by shutting off equipment when not in use or reducing the maximum idling time to five (5) minutes (as required by State Regulations). Clear signage shall be provided for construction workers at all access points.
8. All construction equipment shall be maintained and properly tuned in accordance with manufacturer's specifications. All equipment shall be checked by a certified visible emissions evaluator. Any portable engines greater than 50 horsepower or associated equipment operated within the BAAQMD's jurisdiction shall have either a California Air Resources Board (ARB) registration Portable Equipment Registration Program (PERP) or a BAAQMD permit. For general information regarding the certified visible emissions evaluator or the registration program, visit the ARB FAQ http://www.arb.ca.gov/portable/perp/perpfact_04-16-15.pdf or the PERP website <http://www.arb.ca.gov/portable/portable.htm>.

d. STORM WATER CONTROL

The permittee shall comply with all construction and post-construction storm water pollution prevention protocols as required by the County

7.2 ARCHEOLOGICAL FINDING

In the event that archeological artifacts or human remains are discovered during construction, work shall cease in a 50-foot radius surrounding the area of discovery. The permittee shall contact the PBES Department for further guidance, which will likely include the requirement for the permittee to hire a qualified professional to analyze the artifacts encountered and to determine if additional measures are required.

If human remains are encountered during project development, all work in the vicinity must be halted, and the Napa County Coroner informed, so that the Coroner can determine if an investigation of the cause of death is required, and if the remains are of Native American origin. If the remains are of Native American origin, the permittee shall comply with the requirements of Public Resources Code Section 5097.98.

7.3 CONSTRUCTION NOISE

Construction noise shall be minimized to the greatest extent practical and feasible under State and local safety laws, consistent with construction noise levels permitted by the General Plan Community Character Element and the County Noise Ordinance. Construction equipment muffling and hours of operation shall be in compliance with the County Code. Equipment shall be shut down when not in use. Construction equipment shall normally be staged, loaded, and unloaded on the project site, if at all practicable. If project terrain or access road conditions require construction equipment to be staged, loaded, or unloaded off the project site (such as on a neighboring road or at the base of a hill), such activities shall only occur daily between the hours of 8 am to 5 pm.

7.4 CONSTRUCTION MITIGATION MEASURES [RESERVED]

7.5 OTHER CONSTRUCTION CONDITIONS APPLICABLE TO THE PROJECT PROPOSAL [RESERVED]

8.0 TEMPORARY CERTIFICATE OF OCCUPANCY - PREREQUISITES

A Temporary Certificate of Occupancy (TCO) may be granted pursuant to the County Code to allow the commencement of production activities prior to completion of all project improvements. Permittee shall comply with the following before a TCO is granted:

8.1 TEMPORARY OCCUPANCY

All life and safety conditions shall be addressed prior to issuance of a TCO by the County Building Official. TCOs shall not be used for the occupancy of hospitality buildings and shall not exceed the maximum time allowed by the County Code which is 180 days. Departments and/or agencies with jurisdiction over the project are authorized as part of the TCO process to require a security deposit or other financial instrument to guarantee completion of unfinished improvements.

9.0 FINAL CERTIFICATE OF OCCUPANCY – PREREQUISITES

Permittee shall comply with the following before a Final Certificate of Occupancy is granted by the County Building Official, which upon granting, authorizes all use permit activities to commence.

9.1 FINAL OCCUPANCY

All project improvements, including compliance with applicable codes, conditions, and requirements of all Departments and Agencies with jurisdiction over the project, shall be completed.

9.2 SIGNS

Detailed plans, including elevations, materials, color, and lighting for any winery identification or directional signs shall be submitted to the Department for administrative review and approval prior to installation. Administrative review and approval is not required if signage to be installed is consistent with signage plans submitted, reviewed and approved as part of this permit approval. All signs shall meet the design standards as set forth in the County Code. At least one legible sign shall be placed at the property entrance with the words “Tours and Tasting by Prior Appointment Only” to inform the public of same. Any off-site signs allowed shall be in conformance with the County Code.

9.3 GATES/ENTRY STRUCTURES

Any gate installed at the winery entrance shall be reviewed by the PBES Department and the Fire Department to assure that the design allows large vehicles, such as motorhomes, to turn around if the gate is closed without backing into the public roadway, and that fire suppression access is available at all times. If the gate is part of an entry structure an additional permit shall be required pursuant to the County Code and in accordance with the Napa County Roads and Street Standards. A separate entry structure permit is not required if the entry structure is consistent with entry structure plans submitted, reviewed, and approved as part of this permit approval.

9.4 LANDSCAPING

Landscaping shall be installed in accordance with the approved landscaping plan.

9.5 ROAD OR TRAFFIC IMPROVEMENT REQUIREMENTS [RESERVED]

9.6 DEMOLITION ACTIVITIES [RESERVED]

9.7 GRADING SPOILS

All spoils shall be removed in accordance with the approved grading permit and/or building permit.

9.8 MITIGATION MEASURES APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY [RESERVED]

9.9 OTHER CONDITIONS APPLICABLE PRIOR TO ISSUANCE OF A FINAL
CERTIFICATE OF OCCUPANCY **[RESERVED]**



A Tradition of Stewardship
A Commitment to Service

David Morrison
Director

MEMORANDUM

To: Jason Hade, Planning	From: Jeannette Doss, Engineering <i>JD</i>
Date: March 16, 2018	Re: Dry Creek - Mount Veeder Winery Use Permit – Engineering CoA Mount Veeder Road, Napa, CA P17-00343 & P17-00345 APN: 027-310-039-000

The Engineering Division (Engineering) has reviewed the submittal package for the above proposed project, generally requesting the following:

To establish a new 30,000 gallon winery, construct a new production building, outdoor covered crush pad and work area, construct wine caves, a new residential structure, and associated driveway and parking areas on a parcel located at the intersection of Mount Veeder Road and Dry Creek Road.

Based upon the information provided in the application, Engineering finds the application **complete** and recommends the following conditions of approval:

OPERATIONAL CHARACTERISTICS

1. Any roadway, access drive, and parking area improvements that are required in order to comply with the latest edition of Napa County Road and Street Standards shall be completed **prior to execution** of any new entitlements approved under this Use Permit.

PREREQUISITES FOR ISSUANCE OF PERMITS

2. All on site civil improvements including but not limited to the excavation, fill, general grading, drainage, curb, gutter, surface drainage, storm drainage, parking and drive isles, shall be constructed according to plans prepared by a registered civil engineer, which will be reviewed and approved by the Engineering Division of the Napa County Planning, Building, and Environmental Services Department (PBES) **prior to the commencement** of any on site land preparation or construction. Plans shall be wet signed and submitted with the building and/or grading permit documents at the time of permit application. A plan check fee will apply.

3. **Prior to issuance of a building or grading permit** the owner shall submit the necessary documents for Erosion Control as determined by the area of disturbance of the proposed development in accordance with the Napa Countywide Stormwater Pollution Prevention program Erosion and Sediment Control Plan Guidance for Applicant and Review Staff dated December 2014.
4. **Prior to issuance of a building permit** the owner shall prepare a Regulated Project Stormwater Control Plan (SCP) in accordance with the latest edition of the BASMAA Post-Construction Manual for review and approval by the Engineering Division in PBES.
5. **Prior to issuance of a building or grading permit** the owner shall demonstrate on the plans that all roadways, access driveways, and parking areas serving the project either currently meet the requirements and/or how they will be improved to meet the requirements as outlined in the latest edition of the Napa County Road & Street Standards for Commercial development at the time of approval of this application (P17-00343).
6. **Prior to issuance of a building or grading permit** all newly proposed and/or modified loading areas, outdoor material storage area, trash areas, and processing areas, including but not limited to wine grape crushing/pressing, juice fermentation, blending and fining, filtration and bottling (including mobile bottling), shall be shown on the improvement plans. Areas shall be paved and performed indoors or under cover and graded to preclude stormwater run-on/runoff. The installation of storm drains in processing areas is prohibited. For processing areas that generate liquid wastes, slope the area to a drain an approved collection system.

PREREQUISITES FOR TEMPORARY CERTIFICATE OF OCCUPANCY

7. All roadway, access drive, and parking area improvements shall be completed **prior to issuance of temporary occupancy.**

**** If no temporary occupancy is requested, then the above become requirements prior to final occupancy.**

PREREQUISITES FOR FINAL CERTIFICATION OF OCCUPANCY

8. A registered Civil Engineer shall submit to PBES, Engineering Division written certification of completion of grading in accordance with the approved grading plans prior to requesting final inspection of the building and/or grading permit. Certification shall include line grade, surface drainage, elevation, and location of permitted grading on the lot.
9. Operations and Maintenance Agreement for post construction Stormwater facilities must be legally recorded.

10. Site shall be completely stabilized to the satisfaction of the County Engineer prior to Final Occupancy.

Any changes in use may necessitate additional conditions for approval.

If you have any questions regarding the above items, please contact Jeannette Doss from Napa County Planning, Building, and Environmental Services Department, Engineering and Conservation Division, at (707) 259-8179 or by email at Jeannette.Doss@countyofnapa.org



A Tradition of Stewardship
A Commitment to Service

Planning, Building & Environmental Services

1195 Third Street, Suite 210
Napa, CA 94559
www.countyofnapa.org

David Morrison
Director

MEMORANDUM

To: Jason Hade, Project Planner	From: Kim Withrow, Environmental Health Supervisor
Date: April 6, 2018	Re: Use Permit Application for Dry Creek-Mount Veeder Winery Assessor Parcel 027-310-039 Permit# P17-00343

The application requesting approval to construct an addition onto a new winery and related improvements has been reviewed. This Division has no objection to approval of the application with the following conditions:

Prior to building permit issuance:

1. A permit to destroy the well in the proposed winery construction area must be obtained and work completed by a licensed well driller after use permit approval but prior to building permit approval.
2. Plans for the proposed alternative sewage treatment system shall be designed by a licensed Civil Engineer or Registered Environmental Health Specialist and be accompanied by complete design criteria based upon local conditions. No building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system will be approved until such plans are approved by this Division.
3. A permit to construct the proposed onsite wastewater treatment system must be secured from this Division prior to approval of a building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system.
4. Adequate area must be provided for collection of recyclables. The applicant must work with the franchised garbage hauler for the service area in which they are located, in order to determine the area and the access needed for the collection site. The garbage and recycling enclosure must meet the enclosure requirements provided during use permit process and be included on the building permit submittal. The designated area shall remain available and be properly maintained for its intended use.

5. The proposed water system to serve this project is not currently required to be regulated as a small public water system by this Division under California Code of Regulations, Title 22, or Napa County Code. Therefore, we have no comment as to its adequacy at this time.

The applicant will be required to provide a current water yield test prior to approval of a building permit, and may wish to retain the services of a consultant in this matter. Additionally, 6,000 gallons of domestic water storage will be required to be installed under permit from this Division. The permit must be obtained prior to approval of a building permit.

During construction and/or prior to final occupancy being granted:

6. During the construction, demolition, or renovation period of the project the applicant must use the franchised garbage hauler for the service area in which they are located for all wastes generated during project development, unless applicant transports their own waste. If the applicant transports their own waste, they must use the appropriate landfill or solid waste transfer station for the service area in which the project is located.
7. Pursuant to Chapter 6.95 of the California Health and Safety Code, businesses that store hazardous materials above threshold planning quantities (55 gallons liquid, 200 cubic feet compressed gas, or 500 pounds of solids) shall obtain a permit, file an approved Hazardous Materials Business Plan to <http://cers.calepa.ca.gov/>, and be approved by this Division within 30 days of said activities.
8. An annual alternative sewage treatment system monitoring permit must be obtained for the alternative sewage treatment system /private sewage disposal system prior to issuance of a final on the project. The septic system monitoring, as required by this permit, must be fully complied with.

Upon final occupancy and thereafter:

9. Proposed food service will be catered; therefore, all food must be prepared and served by a Napa County permitted caterer. If the caterer selected does not possess a valid Napa County Permit to operate, refer the business to this Division for assistance in obtaining the required permit prior to providing any food service.
10. The use of the leach field/drain field and reserve area shall be restricted to activities which will not contribute to compaction of the soil with consequent reduction in soil aeration. Activities which must be avoided in the area of the septic system include equipment storage, traffic, parking, pavement, livestock, etc.
11. All solid waste shall be stored and disposed of in a manner to prevent nuisances or health threats from insects, vectors and odors.
12. All diatomaceous earth/bentonite must be disposed of in an approved manner.



A Tradition of Stewardship
A Commitment to Service

Planning, Building, & Environmental Services

1195 Third Street, Suite 210
Napa, CA 94559
www.co.napa.ca.us

Main: (707) 253-4417
Fax: (707) 253-4336

David Morrison
Director

To: Jason Hade, Project Planner	From: Marie Taylor, Building Inspector
Date: October 5, 2017	Re: Use Permit – Mt. Veeder Winery File # P17-00343/345 Address: Dry Creek / Mt Veeder Rd. Napa, Ca. 9494558 APN: 027-310-039

Building Inspection Division; Planning Use Permit Review Comments

The plans provided for the Use Permit application P17-00343/345 do not provide enough information in sufficient detail to determine code requirements. A complete plan check will be performed at the time of application and plan submittal to the building division for required permits. The following are provided to prepare the applicant for some standard submittal requirements for the plan review of the building permit process.

Any existing structures and/or buildings on the property that will be demolished require a separate demolition permit issued by The Napa County Building Division prior to demolition. The applicant will be required to provide a J number form Bay Area Air Quality Management District at the time of application for the permit.

The site and associated buildings are required to be accessible to persons with disabilities. This includes but not limited to, parking, accessible path of travel from parking to all buildings and areas on site that are available to employees and the public. Plans must also include all accessibility features for the interior work. An Accessible Upgrade Worksheet must be submitted with plans as a part of the permit process.

Occupant load will determine occupancy types, exiting requirements, and restroom facilities.

Any change in occupancy or use will require building to comply with the requirements of the California Building Code for a new occupancy or use.

Should you have any questions, please contact Marie Taylor at (707) 299-1359



A Tradition of Stewardship
A Commitment to Service

Department of Public Works

1195 Third Street, Suite 101
Napa, CA 94559-3092
www.countyofnapa.org/publicworks

Main: (707) 253-4351
Fax: (707) 253-4627

Steven Lederer
Director

MEMORANDUM

To: PBES Staff	From: Mike Hawkins Interim Transportation Engineer
Date: January 31, 2018	Re: Dry Creek – Mount Veeder Winery P17-00343-UP/P17-00345-VAR

Thank you for the opportunity to review the Use Permit Application for the above mentioned project. I have reviewed the revised Use Permit Conceptual Site Improvements Grading and Layout Plan dated January 29, 2018 prepared by Applied Civil Engineering and offer the following comments from the Department of Public Works:

No further information needed. The conceptual plans are acceptable and my concerns have been addressed.

Recommended Conditions of Approval. I offer the following recommended conditions of approval:

1. Marketing events should be held at times that preclude adding any new guest traffic to the local circulation system during the peak traffic period. Project Condition: **marketing events of more than 30 visitors shall not begin nor end during the hours of 3-6 PM.**
2. Conceptual layout plans show sight lines from the proposed project driveways will meet standards assuming landscaping is maintained in a manner which does not interfere with these sight lines. Project Condition: **landscaping at the project driveways shall be maintained to not interfere with sight lines required for safe stopping distance on public right-of way. No items that are wider than 18 inches can be taller than 30 inches other than street trees and traffic devices. Street trees should be deciduous and have branches lower than 4 feet in height removed once the tree is established.**

Encroachment Permit required. The plans indicate a new driveway connection to Mount Veeder Road, a County-maintained road. An encroachment permit will be required during the building permit phase. Please contact the Roads office at (707) 944-0196 to initiate the encroachment permit process.

Please contact me at Michael.Hawkins@countyofnapa.org or call (707) 259-8279 if you have questions or need additional information.



A Tradition of Stewardship
A Commitment to Service

Napa County Fire Department
Fire Marshal's Office
Hall of Justice, 2nd Floor
1125 3rd Street
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna
Fire Marshal

MEMORANDUM

TO: Planning Division	DATE: October 20, 2017
FROM: Garrett Veyna Fire Department	
PERMIT: P17-00343	APN: 027-310-039

The Napa County Fire Marshal's Office has reviewed the submittal package for the above proposed project. The Fire Marshal approves as submitted and requires the following conditions to be incorporated as part of permit issuance.

1. All construction and use of the facility shall comply with all applicable standards, regulations, codes and ordinances at time of Building Permit issuance.
2. Beneficial occupancy will not be granted until all fire department fire and life safety items have been installed, tested and finalized.
3. Separate submittals required for Underground Fire Lines, Fire Pump, Automatic Fire Sprinklers, Fire Alarm Systems, Kitchen Hood Extinguishing Systems, High Piled Storage (any combustible stored over 12 feet in height).
4. All buildings, facilities, and developments shall be accessible to fire department apparatus by way of approved access roadways and/or driveways. The fire access road shall comply with the requirements of the Napa County Road & Street Standards. **See Engineering Dept. notes.**
5. Gates for driveways and/or roadways shall comply with the California Fire Code, section 503.5 and the Napa County Road & Street Standards and CA Fire Safe Regulations for projects within SRA.
6. Commercial - Water storage (for buildings not served by a public water system) and fire flow calculations shall be provided by a Certified State Licensed Civil Engineer, C-16 licensed contractor, or registered engineer indicating compliance with **Table B105.2 through Table 105.4 of the Napa County Code Amendments.**
7. Commercial - Approved steamer hydrants shall be installed within 250 feet of any exterior portion of the building as measured along vehicular access roads. Private fire service mains shall be installed, tested and maintained per NFPA 24 2013 edition.



A Tradition of Stewardship
A Commitment to Service

Napa County Fire Department
Fire Marshal's Office
Hall of Justice, 2nd Floor
1125 3rd Street
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna
Fire Marshal

MEMORANDUM

8. Commercial - Fire Department Connections (FDC) for automatic sprinkler systems shall be located fully visible and recognizable from the street or fire apparatus access roads. FDC shall be located within 50 feet of an approved fire hydrant.
9. Commercial - The minimum main size of all fire hydrants shall be 6 inches in diameter. Piping shall be installed with C-900 class 200 piping or ductile iron or equivalent per NFPA 24, 2013 edition for the installation of Underground Fire Protection Mains
10. An automatic fire sprinkler system shall be installed in accordance with provisions set forth in the California Fire Code as amended by the County of Napa and the applicable National Fire Protection Association Standard. Automatic fire sprinkler systems shall be designed by a fire protection engineer or C-16 licensed contractor.
11. All buildings shall comply with California Fire Code, Chapter 10 Means of Egress requirements. Including but not limited to; exit signs, exit doors, exit hardware and exit illumination.
12. Provide 100 feet of defensible space around all structures.
13. Provide 10 feet of defensible space fire hazard reduction on both sides of all roadways of the facility.
14. All cave development shall comply with CBC Section 436 as well as the Napa County Fire Marshal's Office Cave Development Guidelines.

Please note that the comments noted above are based on a Fire Marshal review only. There may be additional comments or information requested from other County Departments or Divisions reviewing this application submittal package. Napa County Fire Marshal's Office Development Guidelines can be found @ www.countyofnapa.org/firemarshal. Should you have any questions of me, contact me at (707)299-1461 or email at garrett.veyna@fire.ca.gov