

**“B”**

## **Recommended Conditions of Approval and Final Agency Approval Memos**

**PLANNING COMMISSION HEARING –SEPTEMBER 19, 2018  
RECOMMENDED CONDITIONS OF APPROVAL**

***MALDONADO WINERY EXPANSION  
USE PERMIT MODIFICATION #P17-00101  
3070 OLD LAWLEY TOLL ROAD, CALISTOGA, CA 94515  
ASSESSOR’S PARCEL #017-140-039***

This permit encompasses and shall be limited to the project commonly known as Maldonado Winery Expansion, located at 3070 Old Lawley Toll Road, Calistoga, CA. Part I encompasses the Project Scope and general conditions pertaining to statutory and local code references, project monitoring, and the process for any future changes or activities. Part II encompasses the ongoing conditions relevant to the operation of the project. Part III encompasses the conditions relevant to construction and the prerequisites for a Final Certificate of Occupancy. It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved.

Where conditions are not applicable or relevant to this project, they shall be noted as “Reserved” and therefore have been removed.

When modifying a legally established entitlement related to this project, these conditions are not intended to be retroactive or to have any effect on existing vested rights except where specifically indicated.

**PART I**

**1.0 PROJECT SCOPE**

This permit shall be limited to:

- 1.1 Approval to modify an existing 15,000 gallon per year winery, previously approved under Use Permit P04-0217-UP to allow the following:
  - a. Increase of production capacity from 15,000 gallons/year to 30,000 gallons/year;
  - b. Maximum number of employees: 2 full-time and 1 part time;
  - c. Installation of a waste water system improvements;
  - d. New access road improvements.

The winery shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code (the County Code). It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved. Any expansion or change in winery use or alternative locations for fire suppression or other types of water tanks shall be approved in accordance with the County Code and may be subject to the permit modification process.

## **2.0 STATUTORY AND CODE SECTION REFERENCES**

All references to statutes and code sections shall refer to their successor as those sections or statutes may be subsequently amended from time to time.

## **3.0 MONITORING COSTS**

All staff costs associated with monitoring compliance with these conditions, previous permit conditions, and project revisions shall be borne by the permittee and/or property owner. Costs associated with conditions of approval and mitigation measures that require monitoring, including investigation of complaints, other than those costs related to investigation of complaints of non-compliance that are determined to be unfounded, shall be charged to the property owner or permittee. Costs shall be as established by resolution of the Board of Supervisors in accordance with the hourly consulting rate established at the time of the monitoring and shall include maintenance of a \$500 deposit for construction compliance monitoring that shall be retained until issuance of a Final Certificate of Occupancy. Violations of conditions of approval or mitigation measures caused by the permittee's contractors, employees, and/or guests are the responsibility of the permittee.

The Planning Commission may implement an audit program if compliance deficiencies are noted. If evidence of a compliance deficiency is found to exist by the Planning Commission at some time in the future, the Planning Commission may institute the program at the applicant's expense (including requiring a deposit of funds in an amount determined by the Commission) as needed until compliance assurance is achieved. The Planning Commission may also use the data, if so warranted, to commence revocation proceedings in accordance with the County Code.

## **PART II**

## **4.0 OPERATIONAL CHARACTERISTICS OF THE PROJECT**

Permittee shall comply with the following during operation of the winery:

### **4.1 GENERAL PROVISIONS**

Consistent with the County Code, tours and tastings and marketing may occur at a winery only where such activities are accessory and "clearly incidental, related, and subordinate to the primary operation of the winery as a production facility."

Tours and tastings (defined below) may include food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery and is incidental to the tasting of wine. Food service may not involve menu options and meal service such that the winery functions as a café or restaurant.

Retail sales of wine shall be permitted as set forth in the County Code.

### **4.2 TOURS AND TASTINGS/VISITATION [RESERVED]**

4.3 **MARKETING [RESERVED]**

4.4 **ON-PREMISES CONSUMPTION [RESERVED]**

4.5 **RESIDENCE OR NON-WINERY STRUCTURES [RESERVED]**

4.6 **GRAPE SOURCE**

At least 75% of the grapes used to make the winery's still wine or the still wine used by the winery to make sparkling wine shall be grown within Napa County. The permittee shall keep records of annual production documenting the source of grapes to verify that 75% of the annual production is from Napa County grapes. The report shall recognize the Agriculture Commission's format for County of origin of grapes and juice used in the Winery Production Process. The report shall be provided to the PBES Department upon request, but shall be considered proprietary information and not available to the public.

4.7 **COMPLIANCE REVIEW**

Permittee shall obtain and maintain all permits (use permits and modifications) and licenses from the California Department of Alcoholic Beverage Control (ABC) and United States Tax and Trade Bureau (TTB), and California Department of Food and Agriculture (CDFA) Grape Crush Inquiry data, all of which are required to produce and sell wine. In the event the required ABC and/or TTB permits and/or licenses are suspended or revoked, permittee shall cease marketing events and tours and tastings until such time as those ABC and/or TTB permits and licenses are reinstated.

Visitation log books, visitor reports, custom crush client records, and any additional documentation determined by Staff to be necessary to evaluate compliance may be requested by the County for any code compliance. The permittee (and their successors) shall be required to participate fully in the winery code compliance review process.

4.8 **RENTAL/LEASING**

No winery facilities, or portions thereof, including, without limitation, any kitchens, barrel storage areas, or warehousing space, shall be rented, leased, or used by entities other than persons producing and/or storing wine at the winery, such as alternating proprietors and custom producers, except as may be specifically authorized in this Permit or pursuant to the Temporary Events Ordinance (County Code Chapter 5.36).

4.9 **GROUND WATER MANAGEMENT - WELLS**

This condition is implemented jointly by the Public Works and PBES Departments:

The permittee shall be required (at the permittee's expense) to record well monitoring data (specifically, static water level no less than quarterly, and the volume of water no less than monthly). Such data will be provided to the County, if the PBES Director determines that substantial evidence<sup>1</sup> indicates that water usage at the winery is affecting, or would potentially affect, groundwater supplies or nearby wells. If data indicates the need for additional monitoring, and if the

applicant is unable to secure monitoring access to neighboring wells, onsite monitoring wells may need to be established to gauge potential impacts on the groundwater resource utilized for the project. Water usage shall be minimized by use of best available control technology and best water management conservation practices.

In order to support the County's groundwater monitoring program, well monitoring data as discussed above will be provided to the County if the Director of Public Works determines that such data could be useful in supporting the County's groundwater monitoring program. The project well will be made available for inclusion in the groundwater monitoring network if the Director of Public Works determines that the well could be useful in supporting the program.

In the event that changed circumstances or significant new information provide substantial evidence<sup>1</sup> that the groundwater system referenced in the Use Permit would significantly affect the groundwater basin, the PBES Director shall be authorized to recommend additional reasonable conditions on the permittee, or revocation of this permit, as necessary to meet the requirements of the County Code and to protect public health, safety, and welfare.

4.10 **AMPLIFIED MUSIC**

There shall be no amplified sound system or amplified music utilized outside of approved, enclosed, winery buildings.

4.11 **TRAFFIC [RESERVED]**

4.12 **PARKING [RESERVED]**

4.13 **BUILDING DIVISION – USE OR OCCUPANCY CHANGES**

Please contact the Building Division with any questions regarding the following:

In accordance with the California Building Code (CBC), no change shall be made in the use of occupancy of an existing building unless the building is made to comply with the requirements of the current CBC for a new building.

4.14 **FIRE DEPARTMENT – TEMPORARY STRUCTURES**

Please contact the Fire Department with any questions regarding the following:

The permittee and/or designee shall obtain a tent permit from the Fire Department for any temporary structures utilized for authorized marketing events allowed per COA No. 4.3 above.

4.15 **NAPA COUNTY MOSQUITO ABATEMENT PROGRAM [RESERVED]**

---

<sup>1</sup> Substantial evidence is defined by case law as evidence that is of ponderable legal significance, reasonable in nature, credible and of solid value. The following constitute substantial evidence: facts, reasonable assumptions predicated on facts; and expert opinions supported by facts. Argument, speculation, unsubstantiated opinion or narrative, or clearly inaccurate or erroneous information do not constitute substantial evidence.

4.16 GENERAL PROPERTY MAINTENANCE – LIGHTING, LANDSCAPING, PAINTING, OUTDOOR EQUIPMENT STORAGE, AND TRASH ENCLOSURE AREAS

- a. All lighting shall be permanently maintained in accordance with the lighting and building plans approved by the County. Lighting utilized during harvest activities is exempt from this requirement.
- b. All landscaping and outdoor screening, storage, and utility structures shall be permanently maintained in accordance with the landscaping and building plans approved by the County. No stored items shall exceed the height of the screening. Exterior winery equipment shall be maintained so as to not create a noise disturbance or exceed noise thresholds in the County Code.
- c. The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division prior to any change in paint colors that differs from the approved building permit. Highly reflective surfaces are prohibited.
- d. Designated trash enclosure areas shall be made available and properly maintained for intended use.

4.17 NO TEMPORARY SIGNS

Temporary off-site signage, such as “A-Frame” signs, is prohibited.

4.18 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – OPERATIONAL CONDITIONS

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies’ requirements. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division operational conditions as stated in their Memorandum dated July 10, 2018.
- b. Environmental Health Division operational conditions as stated in their Memorandum dated April 7, 2018.
- c. Fire Department operational conditions as stated in their Inter-Office Memo dated April 10, 2018.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify this permit.

- 4.19 OPERATIONAL MITIGATION MEASURES **[RESERVED]**
- 4.20 OTHER CONDITIONS APPLICABLE TO THE OPERATIONAL ASPECTS OF THE PROJECT **[RESERVED]**
- 4.21 PREVIOUS CONDITIONS  
The permittee shall comply with the following previous conditions of approval for the winery use as consolidated into the attached document as Exhibit A. To the extent there is a conflict between a previous condition of approval identified in the attached document and these conditions, the more stringent condition shall control.

### **PART III**

#### **5.0 PREREQUISITE FOR ISSUANCE OF PERMITS**

- 5.1 PAYMENT OF FEES  
No building, grading or sewage disposal permits shall be issued or other permits authorized until all accrued planning permit processing fees have been paid in full. This includes all fees associated with plan check and building inspections, associated development impact fees established by County Ordinance or Resolution, and the Napa County Affordable Housing Mitigation Fee in accordance with County Code.

#### **6.0 GRADING/DEMOLITION/ENVIRONMENTAL/BUILDING PERMIT/OTHER PERMIT PREREQUISITES**

Permittee shall comply with the following with the submittal of a grading, demolition, environmental, building and/or other applicable permit applications.

##### **6.1 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – PLAN REVIEW, CONSTRUCTION AND PREOCCUPANCY CONDITIONS**

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies' requirements. The permittee shall comply with all applicable building codes, zoning standards, and requirements of County Divisions, Departments and Agencies at the time of submittal and may be subject to change. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division operational conditions as stated in their Memorandum dated July 10, 2018.
- b. Environmental Health Division operational conditions as stated in their Memorandum dated April 7, 2018.
- c. Fire Department operational conditions as stated in their Inter-Office Memo dated April 10, 2018.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify the permit.

6.2 BUILDING DIVISION – GENERAL CONDITIONS

- a. A building permit shall be obtained for all construction occurring on the site not otherwise exempt by the California Building Code (CBC) or any State or local amendment adopted thereto.
- b. If there are any existing structures and/or buildings on the property that will need to be removed to accommodate construction activities, a separate demolition permit shall be required from the Building Division prior to removal. The permittee shall provide a “J” number from the Bay Area Air Quality Management District (BAAQMD) at the time the permittee applies for a demolition permit if applicable.
- c. All areas of newly designed and newly constructed buildings, facilities and on-site improvements must comply with the CBC accessibility requirements, as well as, American with Disability Act requirements when applicable. When alterations or additions are made to existing buildings or facilities, an accessible path of travel to the specific area of alteration or addition shall be provided as required per the CBC.

6.3 LIGHTING – PLAN SUBMITTAL **[RESERVED]**

6.4 LANDSCAPING – PLAN SUBMITTAL **[RESERVED]**

6.5 COLORS **[RESERVED]**

6.6 OUTDOOR STORAGE/SCREENING/UTILITIES **[RESERVED]**

6.7 TRASH ENCLOSURES **[RESERVED]**

6.8 ADDRESSING **[RESERVED]**

6.9 HISTORIC RESOURCES **[RESERVED]**

6.10 DEMOLITION ACTIVITIES **[RESERVED]**

6.11 VIEWSHED – EXECUTION OF USE RESTRICTION **[RESERVED]**

6.12 PERMIT PREREQUISITE MITIGATION MEASURES **[RESERVED]**

6.13 PARCEL CHANGE REQUIREMENTS **[RESERVED]**

6.14 FINAL MAPS **[RESERVED]**



6.15 OTHER CONDITIONS APPLICABLE TO THE PROJECT PERMITTING PROCESS **[RESERVED]**

**7.0 PROJECT CONSTRUCTION**

Permittee shall comply with the following during project construction:

**7.1 SITE IMPROVEMENTS**

Please contact Engineering Services with any questions regarding the following.

a. **GRADING AND SPOILS**

All grading and spoils generated by construction of the project facilities shall be managed per Engineering Services direction. Alternative locations for spoils are permitted, subject to review and approval by the PBES Director, when such alternative locations do not change the overall concept, and do not conflict with any environmental mitigation measures or conditions of approval.

b. **DUST CONTROL**

Water and/or dust palliatives shall be applied in sufficient quantities during grading and other ground disturbing activities on-site to minimize the amount of dust produced. Outdoor construction activities shall not occur when average wind speeds exceed 20 mph.

c. **AIR QUALITY**

During all construction activities the permittee shall comply with the most current version of BAAQMD Basic Construction Best Management Practices including but not limited to the following, as applicable:

1. Post a publicly visible sign with the telephone number and person to contact at the lead agency regarding dust complaints. The BAAQMD's phone number shall also be visible.
2. Water all exposed surfaces (e.g., parking areas, staging areas, soil piles, grading areas, and unpaved access roads) two times per day.
3. Cover all haul trucks transporting soil, sand, or other loose material off-site.
4. Remove all visible mud or dirt traced onto adjacent public roads by using wet power vacuum street sweepers at least once per day. The use of dry power sweeping is prohibited.
5. All vehicle speeds on unpaved roads shall be limited to 15 mph.
6. All roadways, driveways, and sidewalks to be paved shall be completed as soon as possible. Building pads shall be laid as soon as possible after grading unless seeding or soil binders are used.

7. Idling times shall be minimized either by shutting off equipment when not in use or reducing the maximum idling time to five (5) minutes (as required by State Regulations). Clear signage shall be provided for construction workers at all access points.
8. All construction equipment shall be maintained and properly tuned in accordance with manufacturer's specifications. All equipment shall be checked by a certified visible emissions evaluator. Any portable engines greater than 50 horsepower or associated equipment operated within the BAAQMD's jurisdiction shall have either a California Air Resources Board (ARB) registration Portable Equipment Registration Program (PERP) or a BAAQMD permit. For general information regarding the certified visible emissions evaluator or the registration program, visit the ARB FAQ [http://www.arb.ca.gov/portable/perp/perpfact\\_04-16-15.pdf](http://www.arb.ca.gov/portable/perp/perpfact_04-16-15.pdf) or the PERP website <http://www.arb.ca.gov/portable/portable.htm>.

d. **STORM WATER CONTROL**

The permittee shall comply with all construction and post-construction storm water pollution prevention protocols as required by the County Engineering Services Division, and the California Regional Water Quality Control Board.

7.2 **ARCHEOLOGICAL FINDING**

In the event that archeological artifacts or human remains are discovered during construction, work shall cease in a 50-foot radius surrounding the area of discovery. The permittee shall contact the PBES Department for further guidance, which will likely include the requirement for the permittee to hire a qualified professional to analyze the artifacts encountered and to determine if additional measures are required.

If human remains are encountered during project development, all work in the vicinity must be halted, and the Napa County Coroner informed, so that the Coroner can determine if an investigation of the cause of death is required, and if the remains are of Native American origin. If the remains are of Native American origin, the permittee shall comply with the requirements of Public Resources Code Section 5097.98.

7.3 **CONSTRUCTION NOISE**

Construction noise shall be minimized to the greatest extent practical and feasible under State and local safety laws, consistent with construction noise levels permitted by the General Plan Community Character Element and the County Noise Ordinance. Construction equipment muffling and hours of operation shall be in compliance with the County Code. Equipment shall be shut down when not in use. Construction equipment shall normally be staged, loaded, and unloaded on the project site, if at all practicable. If project terrain or access road conditions require construction equipment to be staged, loaded, or unloaded off the project site (such as on a neighboring road or at the base of a hill), such activities shall only occur daily between the hours of 8 am to 5 pm.

7.4 CONSTRUCTION MITIGATION MEASURES **[RESERVED]**

7.5 OTHER CONSTRUCTION CONDITIONS APPLICABLE TO THE PROJECT PROPOSAL **[RESERVED]**

**8.0 TEMPORARY CERTIFICATE OF OCCUPANCY – PREREQUISITES [RESERVED]**

**9.0 FINAL CERTIFICATE OF OCCUPANCY – PREREQUISITES [RESERVED]**

Permittee shall comply with the following before a Final Certificate of Occupancy is granted by the County Building Official, which upon granting, authorizes all use permit activities to commence.

9.1 FINAL OCCUPANCY **[RESERVED]**

9.2 SIGNS **[RESERVED]**

9.3 GATES/ENTRY STRUCTURES **[RESERVED]**

9.4 LANDSCAPING **[RESERVED]**

9.5 ROAD OR TRAFFIC IMPROVEMENT REQUIREMENTS **[RESERVED]**

9.6 DEMOLITION ACTIVITIES

All demolition activities associated with the changes to the entrance gate shall be completed, landscaping installed, and debris cleared from the subject parcel.

9.7 GRADING SPOILS

All spoils shall be removed in accordance with the approved grading permit and/or building permit.

9.8 MITIGATION MEASURES APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY **[RESERVED]**

9.9 OTHER CONDITIONS APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY **[RESERVED]**

## EXHIBIT A

### PREVIOUS CONDITIONS OF APPROVAL

*Maldonado Winery Expansion  
Use Permit Modification #P17-00101  
3070 Old Lawley Toll Road, Calistoga, Ca 94515  
Assessor Parcel #017-140-039*

#### 4.21 PREVIOUS CONDITIONS

The permittee shall comply with the following previous conditions of approval for the winery use as consolidated into the attached document as Exhibit A. To the extent there is a conflict between a previous condition of approval identified in the attached document and these conditions, the more stringent condition shall control.

#### USE PERMIT # P04-0271-UP

##### COA NO 1

#### 1. SCOPE

Use Permit: To establish a new 15,000 gallon per year winery with:

- A 3,692 square foot building in which 3,306 square feet will be utilized for fermentation, and barrel storage, an office of 192 square feet, a restroom of 96 square feet (located on the second floor) and a laboratory of 96 sq. feet and, 2,800 square feet of caves for barrel storage for a winery totaling 6,492 square feet;
- A 2,700 square foot open crush pad area;
- An 80 square foot outdoor equipment pad;
- A 200 square foot pad area for water tank(s);
- Custom crushing activities (crushing, fermentation, barrel aging and bottling) for up to two custom producers utilizing 50% (7,500 gallons per year) of the total approved winery production capacity;
- One part-time employee;
- Five parking spaces
- A new engineered septic system;
- Up to two water tanks not to exceed 12,000 gallons total; and,
- A new 200 foot driveway.

##### COA NO 2

#### 2. **MARKETING: Marketing events shall be limited as follows:**

- Tour and tastings by appointment only; limited to 4 per day with a maximum of 12 people per day, average of 10 tasting per week not to exceed 30 people per week, not to exceed 20 tastings per week.
- Tours and tastings by appointment only limited to two appointments per year (weekends only) with a maximum of 25 people;
- A marketing plan with two wine and food events per year (weekends only) for members of the wine trade only with a maximum of 15 people and
- One harvest event per year (weekends only) with a maximum of 50 people (No events shall occur at the same time);

**USE PERMIT # P04-0271-UP**

**COA NO 1**

**1.0 SCOPE**

This permit encompasses and shall be limited to:

Construction of a 1050± square foot deck attached to the northern edge of the existing winery building.

The deck shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code. It is the responsibility of the applicant to communicate the requirements of these conditions and mitigations to all designers, contractors, employees and guest of the winery to ensure compliance is achieved. Any expansion or changes in use shall be approved in accordance with County Code Section 18.124.130 and may be subject to the Use Permit modification process.



A Tradition of Stewardship  
A Commitment to Service

**Planning, Building & Environmental Services**

1195 Third Street, Suite 210  
Napa, CA 94559  
www.countyofnapa.org

**David Morrison**  
Director

## MEMORANDUM

To: Wyntress Balcher, Planning	From: Daniel Basore, Engineering
Date: July 10, 2018	Re: P17-00101 Maldonado Winery Use Permit Modification APN: 017-140-039-000

The Engineering and Conservation division ('Engineering') has reviewed the use permit application P17-00101 for the Maldonado Winery Use Permit Modification located on assessor's parcel number 017-140-039-000. In general the project proposes the following:

*"Request to increase production from 15,000 gallons to 30,000 gallons."*

Based upon the information provided in the application, Engineering finds the application **complete** and recommends the following conditions of approval:

### RECOMMENDED APPROVAL CONDITIONS:

#### OPERATIONAL CHARACTERISTICS

1. Should the existing outdoor/uncovered loading/unloading areas and/or processing areas, including but not limited to wine grape crushing/pressing, juice fermentation, blending and fining, filtration and bottling, be modified, expanded and/or improved in the future, Napa County may require these area to be paved and performed undercover.
2. The facility is designated as a discharger that discharges stormwater associated with industrial activity to waters of the United States. Therefore, the facility shall maintain or apply for coverage under the State Water Resources Control Board's Industrial General Permit (IGP), including meeting all applicable provision and protocols of the IGP. If the facility fails to meet the discharge prohibitions of the IGP, Napa County may require the facility to make the necessary improvements to eliminate all exposures to stormwater of the pollutant(s) for which the water body is impaired.

#### PREREQUISITES FOR ISSUANCE OF PERMITS

3. Any roadway, access driveway, and parking areas, proposed new or reconstructed shall meet the requirements as outlined in the latest edition of the Napa County Road & Street Standards for Commercial development at the time of use permit approval. Specifically this project needs will widen the road to 20.0' and existing gate to 22.0' per the submitted plans. A County of Napa Building permit will be required for gate widening.

4. All on site civil improvements including but not limited to the excavation, fill, general grading, drainage, curb, gutter, surface drainage, storm drainage, parking and drive isles, shall be constructed according to plans prepared by a registered civil engineer, which will be reviewed and approved by the Engineering Division of the Napa County Planning, Building, and Environmental Services Department (PBES) **prior to the commencement** of any on site land preparation or construction. Plans shall be wet signed and submitted with the building and/or grading permit documents at the time of permit application. A plan check fee will apply.
5. Grading and drainage improvements shall be constructed according to the current Napa County Road and Street Standards, Chapter 16.28 of the Napa County Code, and Appendix J of the California Building Code.
6. **Prior to issuance of a building permit** the owner shall submit the necessary documents for Erosion Control as determined by the area of disturbance of the proposed development in accordance with the Napa Countywide Stormwater Pollution Prevention program Erosion and Sediment Control Plan Guidance for Applicant and Review Staff dated December 2014.
7. **Prior to issuance of a building permit** the owner shall prepare a Stormwater Control Plan (SCP) if applicable in accordance with the latest edition of the BASMAA Post-Construction Manual for review and approval by the Engineering Division in PBES.

#### **PREREQUISITES FOR TEMPORARY CERTIFICATE OF OCCUPANCY**

8. All roadway improvements shall be completed **prior to execution** of any new entitlements approved under this Use Permit [Modification]. **\*\* If no temporary occupancy is requested, then this becomes a requirement prior to final occupancy.**

#### **PREREQUISITES FOR FINAL CERTIFICATION OF OCCUPANCY**

9. Site shall be completely stabilized to the satisfaction of the County Engineer prior to Final Occupancy.

**Any changes in use may necessitate additional conditions for approval.**

If you have any questions regarding the above items, please contact Daniel Basore from Napa County Planning, Building, and Environmental Services Department, Engineering and Conservation Division, at (707)259-8328 or by email at [Daniel.Basore@countyofnapa.org](mailto:Daniel.Basore@countyofnapa.org)



A Tradition of Stewardship  
A Commitment to Service

Planning, Building & Environmental Services

1195 Third Street, Suite 210  
Napa, CA 94559  
www.countyofnapa.org

David Morrison  
Director

## MEMORANDUM

To: Wyntress Balcher, Project Planner	From: Kim Withrow, Environmental Health Supervisor
Date: May 4, 2018	Re: Maldonado Winery 3070 Old Lawley Toll Road APN: 017-140-039 Project #: P17-00101

Environmental Health Division staff has reviewed a revised application requesting approval to expand production at an existing winery as described in application materials. This Division has no objection to approval of the application with the following conditions of approval:

*Upon Use Permit Approval:*

1. Plans for the proposed alternative sewage treatment system modification(s) as described in the Wastewater Feasibility Study, dated May 2017, included with application materials shall be designed by a licensed Civil Engineer or Registered Environmental Health Specialist and be accompanied by complete design criteria based upon local conditions. No building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system will be approved until such plans are approved by this Division. If no building permits are necessary these plans must be submitted within 60 days or use permit approval and prior to implementing the increase in production.

Please be advised-requirements for process wastewater treatment systems in Napa County are being reviewed and may require modification to comply with Regional Water Quality Control Board (RWQCB) minimum standards.

2. Permit(s) to construct the wastewater treatment system(s) improvements must be secured from this Division prior to approval of a building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system.
3. Annual alternative sewage treatment system monitoring permit(s) must be obtained for the alternative sewage treatment system /private sewage disposal system prior to issuance



---

of a final on the project. The applicant shall comply with required wastewater system monitoring.

4. Within 30 (thirty) days of initiation of the use or change of tenants, an updated Hazardous Materials Business shall be submitted to <http://cers.calepa.ca.gov/> and approved by this Division.
  5. The proposed water system to serve this project is not currently required to be regulated as a small public water system by this Division under California Code of Regulations, Title 22, or Napa County Code. Therefore, we have no comment as to its adequacy at this time.
  6. The use of the wastewater absorption field/drain field area shall be restricted to activities which will not contribute to compaction of the soil with consequent reduction in soil aeration. Activities which must be avoided in the area of the septic system include equipment storage, traffic, parking, pavement, livestock, etc.
  7. All solid waste shall be stored and disposed of in a manner to prevent nuisances or health threats from insects, vectors and odors.
  8. All diatomaceous earth/bentonite must be disposed of in an approved manner. If the proposed septic system is an alternative sewage treatment system the plan submitted for review and approval must address bentonite disposal.
-



A Tradition of Stewardship  
A Commitment to Service

Napa County Fire Department  
Fire Marshal's Office  
Hall of Justice, 2nd Floor  
1125 3rd Street  
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna  
Fire Marshal

## MEMORANDUM

TO: Planning Division	DATE: 4/10/2018
FROM: Chase Beckman Fire Department	
SUBJECT: <b>P17-00101</b>	APN: <b>017-140-039</b>

The Napa County Fire Marshal's Office has reviewed the submittal package for the above proposed project. A re-submittal which addresses the following shall be required.

1. Separate submittals required for Underground Fire Lines, Fire Pump, Automatic Fire Sprinklers, Fire Alarm Systems, Kitchen Hood Extinguishing Systems, High Piled Storage (any combustible stored over 12 feet in height).
2. All buildings, facilities, and developments shall be accessible to fire department apparatus by way of approved access roadways and/or driveways. The fire access road shall comply with the requirements of the Napa County Road & Street Standards (NCRSS).
3. Provide fire department access roads to within 150 feet of any exterior portion of the buildings as measured by an approved route around the exterior of the building or facility.
4. Gates for driveways and/or roadways shall comply with the California Fire Code, section 503.5 and the Napa County Road & Street Standards and CA Fire Safe Regulations for projects within SRA. Please demonstrate dimensions per the NCRSS
5. Commercial - Water storage (for buildings not served by a public water system) and fire flow calculations shall be provided by a Certified State Licensed Civil Engineer, C-16 licensed contractor, or registered engineer indicating compliance with Table B105.2 through Table 105.4 of the Napa County Code Amendments.
6. Commercial - Approved steamer hydrants shall be installed within 250 feet of any exterior portion of the building as measured along vehicular access roads. Private fire service mains shall be installed, tested and maintained per NFPA 24 2013 edition.



A Tradition of Stewardship  
A Commitment to Service

Napa County Fire Department  
Fire Marshal's Office  
Hall of Justice, 2nd Floor  
1125 3rd Street  
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna  
Fire Marshal

## MEMORANDUM

7. Commercial - Fire Department Connections (FDC) for automatic sprinkler systems shall be located fully visible and recognizable from the street or fire apparatus access roads. FDC shall be located within 50 feet of an approved fire hydrant.
8. Commercial - The minimum main size of all fire hydrants shall be 6 inches in diameter. Piping shall be installed with C-900 class 200 piping or ductile iron or equivalent per NFPA 24, 2013 edition for the installation of Underground Fire Protection Mains

Please note that the comments noted above are based on a Fire Marshal review only. There may be additional comments or information requested from other County Departments or Divisions reviewing this application submittal package. Napa County Fire Marshal's Office Development Guidelines can be found @ [www.countyofnapa.org/firemarshal](http://www.countyofnapa.org/firemarshal). Should you have any questions of me, contact me at (707)299-1462 or email at [chase.beckman@fire.ca.gov](mailto:chase.beckman@fire.ca.gov)