

**“B”**

**Recommended Conditions of Approval  
and Final Agency Approval Memos**

**PLANNING COMMISSION HEARING – OCTOBER 16, 2019  
RECOMMENDED CONDITIONS OF APPROVAL**

**KITOKO WINERY  
USE PERMIT P17-00373-UP  
3201 ATLAS PEAK ROAD, NAPA  
ASSESSOR PARCEL NO. 033-010-034**

This permit encompasses and shall be limited to the project commonly known as **Kitoko Winery**, located at 3201 Atlas Peak Road. Part I encompasses the Project Scope and general conditions pertaining to statutory and local code references, project monitoring, and the process for any future changes or activities. Part II encompasses the ongoing conditions relevant to the operation of the project. Part III encompasses the conditions relevant to construction and the prerequisites for a Final Certificate of Occupancy. It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved.

Where conditions are not applicable or relevant to this project, they shall be noted as “Reserved” and therefore have been removed.

When modifying a legally established entitlement related to this project, these conditions are not intended to be retroactive or to have any effect on existing vested rights except where specifically indicated.

**PART I**

**1.0 PROJECT SCOPE**

The permit encompasses and shall be limited to:

- 1.1 Approval of a Use Permit for a new 40,000-gallon per year winery to allow the following
  - a. Construction of a winery building consisting of two detached structures (3,187 sf and 2,603 sf) joined in the center by a covered crush pad (1,658 sf). Mobile bottling activities will occur in the crush pad area;
  - b. Construction of an approximately 13,662 sf cave with access by three (3) portals. One portal will be accessed from the new winery building and one will be accessed from the covered crush pad and the third will be accessed from the turn-around area located at the western portion of the project. The cave will be use primary for production with the exception of a 420 sf hospitality room;
  - c. Visitation, tours and tastings, and a marketing plan as set forth in Conditions of Approval (COAs) Nos. 4.1 through 4.3 below;
  - d. On-premise consumption of wines as set forth in Condition of Approval No. 4.4 below;
  - e. Four (4) full-time and three (3) part-time employees; During harvest on a weekday, there will be 5 full-time employees and 1 part-time employee and 3 full-time employees on a harvest weekend;

- f. Winery hours of operation Monday through Sunday 7 am – 6 pm (Non-harvest Production) and 10 am – 6 pm (Visitation);
- g. Construction of seven (7) parking spaces;
- h. Installation of a wastewater system with tanks above or below ground;
- i. Installation of a well and a public water system;
- j. Installation of an underground or above ground water storage system for fire protection and rain water collection (50,000 +/- gallons);
- k. Installation of a 10,000 gallon domestic water tank;
- l. A new access driveway; and
- m. All project spoils and rocks generated from the cave and construction activities to be disposed on-site in front of the proposed winery.

The winery shall be designed in substantial conformance with the submitted site plan, elevation drawings, and other submittal materials and shall comply with all requirements of the Napa County Code (the County Code). It is the responsibility of the permittee to communicate the requirements of these conditions and mitigations (if any) to all designers, contractors, employees, and guests of the winery to ensure compliance is achieved. Any expansion or change in winery use or alternative locations for fire suppression or other types of water tanks shall be approved in accordance with the County Code and may be subject to the permit modification process.

## **2.0 STATUTORY AND CODE SECTION REFERENCES**

All references to statutes and code sections shall refer to their successor as those sections or statutes may be subsequently amended from time to time.

## **3.0 MONITORING COSTS**

All staff costs associated with monitoring compliance with these conditions, previous permit conditions, and project revisions shall be borne by the permittee and/or property owner. Costs associated with conditions of approval and mitigation measures that require monitoring, including investigation of complaints, other than those costs related to investigation of complaints of non-compliance that are determined to be unfounded, shall be charged to the property owner or permittee. Costs shall be as established by resolution of the Board of Supervisors in accordance with the hourly consulting rate established at the time of the monitoring and shall include maintenance of a \$500 deposit for construction compliance monitoring that shall be retained until issuance of a Final Certificate of Occupancy. Violations of conditions of approval or mitigation measures caused by the permittee's contractors, employees, and/or guests are the responsibility of the permittee.

The Planning Commission may implement an audit program if compliance deficiencies are noted. If evidence of a compliance deficiency is found to exist by the Planning Commission at some time in the future, the Planning Commission may institute the program at the applicant's expense (including requiring a deposit of funds in an amount determined by the Commission) as needed until compliance assurance is achieved. The Planning Commission may also use the data, if so warranted, to commence revocation proceedings in accordance with the County Code.

## PART II

### 4.0 OPERATIONAL CHARACTERISTICS OF THE PROJECT

Permittee shall comply with the following during operation of the winery:

#### 4.1 GENERAL PROVISIONS

Consistent with the County Code, tours and tastings and marketing may occur at a winery only where such activities are accessory and “clearly incidental, related, and subordinate to the primary operation of the winery as a production facility.”

Tours and tastings (defined below) may include food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery and is incidental to the tasting of wine. Food service may not involve menu options and meal service such that the winery functions as a café or restaurant.

Retail sales of wine shall be permitted as set forth in the County Code.

#### 4.2 TOURS AND TASTINGS/VISITATION

Tours and tastings shall be by appointment only and shall be limited to the following:

- a. Frequency: 7 days per week, Monday through Sunday
- b. Maximum number of persons per day: 20
- c. Maximum number of persons per week: 140
- d. Hours of visitation: 10 a.m. to 6 p.m.

“Tours and tastings” means tours of the winery and/or tastings of wine, where such tours and tastings are limited to persons who have made unsolicited prior appointments for tours or tastings. To the maximum extent feasible, scheduling of visitors shall not occur during peak travel times (Between 3:00 p.m. - 5:30 p.m.).

A log book (or similar record) shall be maintained to document the number of visitors to the winery (for either tours and tastings or marketing events), and the dates of the visits. This record of visitors shall be made available to the Planning, Building and Environmental Services (PBES) Department upon request.

#### 4.3 MARKETING

Marketing events shall be limited to the following:

- a. Event Type 1
  1. Frequency: 10 per year
  2. Maximum number of persons: 30
  3. Time of Day: 10 a.m. to 6 p.m. or 7 p.m. to 10 p.m.
  4. Shuttle service will be used during evening events.
  5. Food to be prepared by a caterer.

- b. Event Type 2
  - 1. Frequency: One (1) per year
  - 2. Maximum number of persons: 100
  - 3. Time of Day: 10 a.m. to 6 p.m. and 7 p.m. to 10 p.m.
  - 4. Portable toilet facilities for guest use shall be required.
  - 5. Shuttle service will be used during evening events.
  - 6. Food to be prepared by a catered.
- c. No marketing events will be scheduled between 3:00 and 5:30 p.m.

"Marketing of wine" means any activity of a winery which is conducted at the winery on a prearranged basis for the education and development of customers and potential customers with respect to wine which can be sold at the winery on a retail basis pursuant to the County Code. Marketing of wine may include cultural and social events directly related to the education and development of customers and potential customers provided such events are clearly incidental, related and subordinate to the primary use of the winery. Marketing of wine may include food service, including food and wine pairings, where all such food service is provided without charge except to the extent of cost recovery.

Business events are similar to cultural and social events, in that they will only be considered as "marketing of wine" if they are directly related to the education and development of customers and potential customers of the winery and are part of a marketing plan approved as part of the winery's Use Permit. To be considered directly related to the education and development of customers or potential customers of the winery, business events must be conducted at no charge except to the extent of cost recovery, and any business content unrelated to wine must be limited.

Careful consideration shall be given to the intent of the event, the proportion of the business event's non-wine-related content, and the intensity of the overall marketing plan (County Code).

All marketing event activity, excluding quiet clean-up, shall cease by 10 p.m. If any event is held which will exceed the available on-site parking, the permittee shall prepare an event-specific parking plan which may include, but not be limited to, valet service or off-site parking and shuttle service to the winery.

Auction Napa Valley (ANV) events need not be included in a participating winery's marketing plan because they are covered by ANV's Category 5 Temporary Permit. The winery may utilize any ANV event authorized in this permit for another charitable event of similar size.

#### 4.4 ON-PREMISES CONSUMPTION

In accordance with State law and the PBES Director's July 17, 2008 memo, "Assembly Bill 2004 (Evans) & the Sale of Wine for Consumption On-Premises," on-premises consumption of wine produced on-site and purchased from the winery may occur solely within the outdoor patio area and hospitality building designated tasting areas. Any and all visitation associated with on-premises consumption shall be subject to the maximum per person weekday and weekend

daily tours and tastings visitation limitation and/or applicable limitations of permittee's marketing plan set forth in COA Nos.4.2 and 4.3 above.

4.5 RESIDENCE OR NON-WINERY STRUCTURES

Unless specifically authorized by this permit or a previously approved permit, the single-family residence, barn and various agricultural outbuilding when rebuilt shall not be used for commercial purposes or in conjunction with the operation and/or visitation/marketing program for the winery. If the residence is rented, it shall only be rented for periods of 30 days or more, pursuant to the County Code.

4.6 GRAPE SOURCE

At least 75% of the grapes used to make the winery's still wine or the still wine used by the winery to make sparkling wine shall be grown within Napa County. The permittee shall keep records of annual production documenting the source of grapes to verify that 75% of the annual production is from Napa County grapes. The report shall recognize the Agriculture Commission's format for County of origin of grapes and juice used in the Winery Production Process. The report shall be provided to the PBES Department upon request, but shall be considered proprietary information and not available to the public.

4.7 COMPLIANCE REVIEW

Permittee shall obtain and maintain all permits (use permits and modifications) and licenses from the California Department of Alcoholic Beverage Control (ABC) and United States Tax and Trade Bureau (TTB), and California Department of Food and Agriculture (CDFA) Grape Crush Inquiry data, all of which are required to produce and sell wine. In the event the required ABC and/or TTB permits and/or licenses are suspended or revoked, permittee shall cease marketing events and tours and tastings until such time as those ABC and/or TTB permits and licenses are reinstated.

Visitation log books, visitor reports, custom crush client records, and any additional documentation determined by Staff to be necessary to evaluate compliance may be requested by the County for any code compliance. The permittee (and their successors) shall be required to participate fully in the winery code compliance review process.

4.8 RENTAL/LEASING

No winery facilities, or portions thereof, including, without limitation, any kitchens, barrel storage areas, or warehousing space, shall be rented, leased, or used by entities other than persons producing and/or storing wine at the winery, such as alternating proprietors and custom producers, except as may be specifically authorized in this Permit or pursuant to the Temporary Events Ordinance (County Code Chapter 5.36).

4.9 GROUND WATER MANAGEMENT - WELLS

This condition is implemented jointly by the Public Works and PBES Departments:

The permittee shall be required (at the permittee's expense) to record well monitoring data (specifically, static water level no less than quarterly, and the volume of water no less than monthly). Such data will be provided to the County, if the PBES Director determines that substantial evidence<sup>1</sup> indicates that water usage at the winery is affecting, or would potentially affect, groundwater supplies or nearby wells. If data indicates the need for additional monitoring, and if the applicant is unable to secure monitoring access to neighboring wells, onsite monitoring wells may need to be established to gauge potential impacts on the groundwater resource utilized for the project. Water usage shall be minimized by use of best available control technology and best water management conservation practices.

In order to support the County's groundwater monitoring program, well monitoring data as discussed above will be provided to the County if the Director of Public Works determines that such data could be useful in supporting the County's groundwater monitoring program. The project well will be made available for inclusion in the groundwater monitoring network if the Director of Public Works determines that the well could be useful in supporting the program.

In the event that changed circumstances or significant new information provide substantial evidence<sup>1</sup> that the groundwater system referenced in the Use Permit would significantly affect the groundwater basin, the PBES Director shall be authorized to recommend additional reasonable conditions on the permittee, or revocation of this permit, as necessary to meet the requirements of the County Code and to protect public health, safety, and welfare.

4.10 AMPLIFIED MUSIC

There shall be no amplified sound system or amplified music utilized outside of approved, enclosed, winery buildings.

4.11 TRAFFIC

To the maximum extent feasible, scheduling of reoccurring vehicle trips to and from the site for employees and deliveries shall not occur during peak travel times (between 3:00 p.m. - 5:30 p.m.). All road improvements on private property required per Engineering Services shall be maintained in good working condition and in accordance with the Napa County Roads and Streets Standards.

---

<sup>1</sup> Substantial evidence is defined by case law as evidence that is of ponderable legal significance, reasonable in nature, credible and of solid value. The following constitute substantial evidence: facts, reasonable assumptions predicated on facts; and expert opinions supported by facts. Argument, speculation, unsubstantiated opinion or narrative, or clearly inaccurate or erroneous information do not constitute substantial evidence.

4.12 PARKING

The location of visitor parking and truck loading zone areas shall be identified along with proposed circulation and traffic control signage (if any).

Parking shall be limited to approved parking spaces only and shall not occur along access or public roads or in other locations except during harvest activities and approved marketing events. In no case shall parking impede emergency vehicle access or public roads.

4.13 BUILDING DIVISION – USE OR OCCUPANCY CHANGES

Please contact the Building Division with any questions regarding the following: In accordance with the California Building Code (CBC), no change shall be made in the use of occupancy of an existing building unless the building is made to comply with the requirements of the current CBC for a new building.

4.14 FIRE DEPARTMENT – TEMPORARY STRUCTURES

Please contact the Fire Department with any questions regarding the following:

The permittee and/or designee shall obtain a tent permit from the Fire Department for any temporary structures utilized for authorized marketing events allowed per COA No. 4.3 above.

4.15 NAPA COUNTY MOSQUITO ABATEMENT PROGRAM **[RESERVED]**

4.16 GENERAL PROPERTY MAINTENANCE – LIGHTING, LANDSCAPING, PAINTING, OUTDOOR EQUIPMENT STORAGE, AND TRASH ENCLOSURE AREAS

- a. All lighting shall be permanently maintained in accordance with the lighting and building plans approved by the County. Lighting utilized during harvest activities is exempt from this requirement.
- b. All landscaping and outdoor screening, storage, and utility structures shall be permanently maintained in accordance with the landscaping and building plans approved by the County. No stored items shall exceed the height of the screening. Exterior winery equipment shall be maintained so as to not create a noise disturbance or exceed noise thresholds in the County Code.
- c. The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division prior to any change in paint colors that differs from the approved building permit. Highly reflective surfaces are prohibited.
- d. Designated trash enclosure areas shall be made available and properly maintained for intended use.



4.17 NO TEMPORARY SIGNS

Temporary off-site signage, such as “A-Frame” signs, is prohibited.

4.18 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – OPERATIONAL CONDITIONS

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies’ requirements. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division operational conditions as stated in their Memorandum dated May 17, 2018.
- b. Environmental Health Division operational conditions as stated in their Memorandum dated December 21, 2018.
- c. Building Inspection Division plan operational conditions as stated in their Memorandum dated November 29, 2017.
- d. CalFire operational conditions as stated in their Memorandum dated December 21, 2017.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify this permit.

4.19 OPERATIONAL MITIGATION MEASURES

The permittee shall comply with the following operational mitigation measures identified in the adopted Initial Study/Mitigated Negative Declaration and Project Revision Statement/Mitigation Monitoring and Reporting Program prepared for the project:

- a. MM Trans – 2: The permittee shall remove brush on an annual basis along the project’s Atlas Peak Road frontage to the north and south of the project driveway in order to maintain acceptable sight lines to accommodate 30 mile per hour traffic speeds on Atlas Peak Road.

Method of Monitoring: Prior to the issuance of a building permit, an annual landscape maintenance program in conjunction with the project’s landscape plan shall be submitted to the Planning Division and the Public Works Department for review and approval.

Responsible Agency(ies): Planning Division and Public Works

4.20 OTHER CONDITIONS APPLICABLE TO THE OPERATIONAL ASPECTS OF THE PROJECT **[RESERVED]**

4.21 PREVIOUS CONDITIONS **[RESERVED]**

### **PART III**

#### **5.0 PREREQUISITE FOR ISSUANCE OF PERMITS**

##### **5.1 PAYMENT OF FEES**

No building, grading or sewage disposal permits shall be issued or other permits authorized until all accrued planning permit processing fees have been paid in full. This includes all fees associated with plan check and building inspections, associated development impact fees established by County Ordinance or Resolution, and the Napa County Affordable Housing Mitigation Fee in accordance with County Code.

#### **6.0 GRADING/DEMOLITION/ENVIRONMENTAL/BUILDING PERMIT/OTHER PERMIT PREREQUISITES**

Permittee shall comply with the following with the submittal of a grading, demolition, environmental, building and/or other applicable permit applications.

##### **6.1 COMPLIANCE WITH OTHER DEPARTMENTS AND AGENCIES – PLAN REVIEW, CONSTRUCTION AND PREOCCUPANCY CONDITIONS**

The attached project conditions of approval include all of the following County Divisions, Departments and Agencies' requirements. The permittee shall comply with all applicable building codes, zoning standards, and requirements of County Divisions, Departments and Agencies at the time of submittal and may be subject to change. Without limiting the force of those other requirements which may be applicable, the following are incorporated by reference as enumerated herein:

- a. Engineering Services Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated May 17, 2018.
- b. Environmental Health Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated December 21, 2018.
- c. Building Inspection Division plan review/construction/ preoccupancy conditions as stated in their Memorandum dated November 29, 2017.
- d. Cal Fire plan review/ construction/ preoccupancy conditions as stated in their Memorandum dated December 21, 2017.

The determination as to whether or not the permittee has substantially complied with the requirements of other County Divisions, Departments and Agencies shall be determined by those County Divisions, Departments or Agencies. The inability to substantially comply with the requirements of other County Divisions, Departments and Agencies may result in the need to modify the permit.

## 6.2 BUILDING DIVISION – GENERAL CONDITIONS

- a. A building permit shall be obtained for all construction occurring on the site not otherwise exempt by the California Building Code (CBC) or any State or local amendment adopted thereto.
- b. If there are any existing structures and/or buildings on the property that will need to be removed to accommodate construction activities, a separate demolition permit shall be required from the Building Division prior to removal. The permittee shall provide a “J” number from the Bay Area Air Quality Management District (BAAQMD) at the time the permittee applies for a demolition permit if applicable.
- c. All areas of newly designed and newly constructed buildings, facilities and on-site improvements must comply with the CBC accessibility requirements, as well as, American with Disability Act requirements when applicable. When alterations or additions are made to existing buildings or facilities, an accessible path of travel to the specific area of alteration or addition shall be provided as required per the CBC.

## 6.3 LIGHTING – PLAN SUBMITTAL

- a. Two (2) copies of a detailed lighting plan showing the location and specifications for all lighting fixtures to be installed on the property shall be submitted for Planning Division review and approval. All lighting shall comply with the CBC.
- b. All exterior lighting, including landscape lighting, shall be shielded and directed downward, shall be located as low to the ground as possible, shall be the minimum necessary for security, safety, or operations; on timers; and shall incorporate the use of motion detection sensors to the greatest extent practical. All lighting shall be shielded or placed such that it does not shine directly on adjacent properties or impact vehicles on adjacent streets. No flood-lighting or sodium lighting of the building is permitted, including architectural highlighting and spotting. Low-level lighting shall be utilized in parking areas as opposed to elevated high-intensity light standards. Lighting utilized during harvest activities is exempt from this requirement.

## 6.4 LANDSCAPING – PLAN SUBMITTAL

- a. Two (2) copies of a detailed final landscaping and irrigation plan, including parking details, shall be submitted with the building permit application package for the Planning Division’s review and approval prior to the issuance of any building permit associated with this Use Permit. The plan shall be prepared pursuant to the County’s Water Efficient Landscape Ordinance (Chapter 18.118 of the County Code) requirements in effect at the time of building permit application submittal, as applicable, and shall indicate the names and locations of all plant materials to be used along with their method of maintenance.

- b. Plant materials shall be purchased locally when practical, and to the greatest extent possible, the plant materials shall be the same native plants found in Napa County. The Agricultural Commissioner's office shall be notified of all impending deliveries of live plants with points of origin outside of Napa County.
- c. No trees greater than 6" diameter at breast height shall be removed, except for those identified on the submitted site plan. Any Oak trees removed as a result of the project shall be replaced at a 2:1 ratio and shown on the landscaping plans for the Planning Division's review and approval. Trees to be retained shall be protected during construction by fencing securely installed at the outer most dripline of the tree or trees. Such fencing shall be maintained throughout the duration of the work undertaken in connection with the winery development/construction. In no case shall construction material, debris or vehicles be stored in the fenced tree protection area.
- d. Evergreen screening shall be installed between the industrial portions of the operation (e.g. tanks, crushing area, parking area, etc.) and any off-site residence from which these areas can be viewed.

#### 6.5 COLORS

The colors used for the roof, exterior walls and built landscaping features of the winery shall be limited to earth tones that will blend the facility into the colors of the surrounding site specific vegetation. The permittee shall obtain the written approval of the Planning Division in conjunction with building permit review and/or prior to painting the building. Highly reflective surfaces are prohibited.

#### 6.6 OUTDOOR STORAGE/SCREENING/UTILITIES

- a. Details of outdoor storage areas and structures shall be included on the building and landscape plans. All outdoor storage of winery equipment shall be screened from the view of residences of adjacent properties by a visual barrier consisting of fencing or dense landscaping. No stored item shall exceed the height of the screening. Water and fuel tanks, and similar structures, shall be screened to the extent practical so as to not be visible from public roads and adjacent parcels.
- b. New utility lines required for this project that are visible from any designated scenic transportation route (see Community Character Element of the General Plan and the County Code) shall be placed underground or in an equivalent manner be made virtually invisible from the subject roadway.
- c. Exterior winery equipment shall be located, enclosed or muffled so as not to exceed noise thresholds in the County Code.

#### 6.7 TRASH ENCLOSURES

Adequate area must be provided for collection and loading of garbage and recyclables generated by the project. The applicant must work with the

franchised garbage hauler for the service area in which they are located, in order to determine the area and the pedestrian and vehicle access needed for the collection site. The garbage and recycling enclosure shall meet the minimum enclosure requirements established by staff and the franchised hauler, which shall be included in the building permit submittal.

6.8 ADDRESSING

All project site addresses shall be determined by the PBES Director, and be reviewed and approved by the United States Post Office. The PBES Director reserves the right to issue or re-issue an appropriate situs address at the time of issuance of any building permit to ensure proper identification and sequencing of numbers. For multi-tenant or multiple structure projects, this includes building permits for later building modifications or tenant improvements.

6.9 HISTORIC RESOURCES [RESERVED]

6.10 DEMOLITION ACTIVITIES [RESERVED]

6.11 VIEWSHED – EXECUTION OF USE RESTRICTION [RESERVED]

6.12 PERMIT PREREQUISITE MITIGATION MEASURES

The permittee shall comply with the following permit prerequisite mitigation measures identified in the adopted Initial Study/Mitigated Negative Declaration and Project Revision Statement/Mitigation Monitoring and Reporting Program prepared for the project:

- a. MM BIO-1: Development of the proposed project would have the potential to affect populations of Napa bluecurls (CNPS List 1B.2) within the project area, in conflict with General Plan Goal CON-3 (and related Policies) that require the protection of special status species. Impacts to Napa County Locally Rare species would conflict with Goal CON-2 that requires the maintenance and enhancement of existing levels of biodiversity. Policy CON-13 requires that all discretionary agricultural projects consider and address impacts to wildlife habitat and avoid impacts to fisheries and habitat supporting special-status species to the extent feasible.

The plan shall be modified to include the following combination of mitigation measures to avoid and replace populations of Napa bluecurls within the project parcel:

Avoidance

Populations of Napa bluecurls within the study area shall be avoided to the extent feasible through project redesign at the building permit phase. Minimum 25-foot buffers shall be established and maintained between all development areas (including but not limited to landscaping and infrastructure) of remaining populations of Napa bluecurls.

Replacement/Restoration

All populations of Napa bluecurls removed shall be replaced at a minimum 2:1 ratio (population areas replaced: population areas removed)

or greater as determined by and in consultation with the California Department of Fish and Wildlife (CDFW) and Napa County. Mitigation replanting shall be designated in a Mitigation Plan, which would include replanting procedures, monitoring requirements, and success criteria goals. Replanting areas shall be determined by a qualified biologist in consultation with CDFW. Planting densities would be determined by a qualified biologist during preconstruction surveys and shall be similar to existing densities found onsite.

#### Preservation

Areas containing Napa bluecurls that remain undeveloped shall be preserved and managed to maintain a relatively open canopy as determined by and in consultation with the California Department of Fish and Wildlife. A qualified biologist shall verify that markers and visible fencing protect these areas and are positioned correctly and adequately for each phase of the project. These areas may be inspected for compliance before, during, and after each construction phase.

The areas selected for preservation shall include those areas required to be avoided as mitigation and provide potential habitat for Napa bluecurls. Areas designated for preservation shall be identified as such in a deed restriction or mitigation easement with an organization such as the Land Trust of Napa County as the grantee, or other means of permanent protection. Land placed in protection shall be restricted from development and other uses that would potentially degrade the quality of the habitat (including, but not limited to, conversion to other land uses such as agriculture or urban development, and excessive off-road vehicle use that increases erosion), and should otherwise be restricted by the existing goals and policies of Napa County. The areas to be covered by the deed restriction shall be determined by and in consultation with the California Department of Fish and Wildlife, and submitted to Napa County for review and approval. Areas to be preserved shall be selected in a manner that minimizes fragmentation of habitat areas; and the preservation areas shall first prioritize portions of the project that are not already subject to development restrictions (i.e. within stream setbacks and on slopes greater than 30%). The deed restriction or mitigation easement shall be entered into and recorded with the Napa County Recorder's office prior to commencement of the project or within 90 days of project approval, whichever occurs first, and in a form acceptable to County Counsel.

Method of Monitoring: Prior to issuance of a grading permit, the Napa bluecurl Mitigation Plan shall be reviewed and approved by the Planning Division in consultation with CDFW and implemented for any removal and/or replanting of Napa bluecurls.

Responsible Agency(ies): Planning Division

- b. MM BIO-2: Pre-construction Bird Surveys: If vegetation removal takes place during the breeding/nesting season (February 1 through August

31), disturbance of nesting activities could occur. Take of any active raptor nest is prohibited under California Fish and Game Code Sections 3503, 3503.5, and 3513. To avoid impacts to nesting birds, necessary tree and shrub removal should occur outside of the typical nesting season (February 1 through August 31). If tree or shrub removal occurs at any time during the nesting season, a preconstruction survey should be conducted by a qualified biologist no more than 15 days prior to initiation of proposed development activities. If active nests are found on or immediately adjacent to the site, a nest avoidance plan shall be implemented with approval from the Napa County Planning Department. The avoidance plan shall include appropriate buffers to the nest(s), and a qualified biologist should monitor the nest(s) and project activities to ensure no harm or agitation affects the nestlings. Once the birds have fledged, there is no longer a need for the buffer, and project activities could then proceed. If no nesting is found to occur, necessary tree and shrub removal could then proceed.

Method of Monitoring: If vegetation clearing or other land disturbance is proposed during the bird breeding season (February 1 through August 31), the special-status bird species and other migratory passerines (perching birds) survey shall be submitted to Planning Division staff prior to issuance of the grading permit.

Responsible Agency(ies): Planning Division

- c. MM Trans – 1: The permittee shall provide a sign along the project driveway for exiting traffic directing drivers desiring to travel up the Napa Valley to make a right turn at the signalized Atlas Peak Road/Monticello (SR121) intersection to access either Silverado Trail or SR 29.

Method of Monitoring: Improvement Plans for the installation of the directional sign and an application for an encroachment permit shall be submitted for Engineering Services and the Planning Division and the Public Works Department review and approval prior to the issuance of a building permit or grading permit.

Responsible Agency(ies): Planning Division and Public Works

- d. MM Trans – 2: The permittee shall remove brush on an annual basis along the project's Atlas Peak Road frontage to the north and south of the project driveway in order to maintain acceptable sight lines to accommodate 30 mile per hour traffic speeds on Atlas Peak Road.

Method of Monitoring: Prior to the issuance of a building permit, an annual landscape maintenance program in conjunction with the project's landscape plan shall be submitted to the Planning Division and the Public Works Department for review and approval.

Responsible Agency(ies): Planning Division and Public Works

6.13 PARCEL CHANGE REQUIREMENTS **[RESERVED]**

6.14 FINAL MAPS **[RESERVED]**

6.15 OTHER CONDITIONS APPLICABLE TO THE PROJECT PERMITTING PROCESS

- a. Prior to the issuance of a grading or building permit, the permittee shall obtain an encroachment permit from the Public Works Department for any new improvements to the Atlas Peak Road driveway entrance.

## **7.0 PROJECT CONSTRUCTION**

Permittee shall comply with the following during project construction:

### **7.1 SITE IMPROVEMENTS**

Please contact Engineering Services with any questions regarding the following.

#### **a. GRADING AND SPOILS**

All grading and spoils generated by construction of the project facilities shall be managed per Engineering Services direction. Alternative locations for spoils are permitted, subject to review and approval by the PBES Director, when such alternative locations do not change the overall concept, and do not conflict with any environmental mitigation measures or conditions of approval.

#### **b. DUST CONTROL**

Water and/or dust palliatives shall be applied in sufficient quantities during grading and other ground disturbing activities on-site to minimize the amount of dust produced. Outdoor construction activities shall not occur when average wind speeds exceed 20 mph.

#### **c. AIR QUALITY**

During all construction activities the permittee shall comply with the most current version of BAAQMD Basic Construction Best Management Practices including but not limited to the following, as applicable:

1. Post a publicly visible sign with the telephone number and person to contact at the lead agency regarding dust complaints. The BAAQMD's phone number shall also be visible.
2. Water all exposed surfaces (e.g., parking areas, staging areas, soil piles, grading areas, and unpaved access roads) two times per day.
3. Cover all haul trucks transporting soil, sand, or other loose material off-site.



4. Remove all visible mud or dirt traced onto adjacent public roads by using wet power vacuum street sweepers at least once per day. The use of dry power sweeping is prohibited.
5. All vehicle speeds on unpaved roads shall be limited to 15 mph.
6. All roadways, driveways, and sidewalks to be paved shall be completed as soon as possible. Building pads shall be laid as soon as possible after grading unless seeding or soil binders are used.
7. Idling times shall be minimized either by shutting off equipment when not in use or reducing the maximum idling time to five (5) minutes (as required by State Regulations). Clear signage shall be provided for construction workers at all access points.
8. All construction equipment shall be maintained and properly tuned in accordance with manufacturer's specifications. All equipment shall be checked by a certified visible emissions evaluator. Any portable engines greater than 50 horsepower or associated equipment operated within the BAAQMD's jurisdiction shall have either a California Air Resources Board (ARB) registration Portable Equipment Registration Program (PERP) or a BAAQMD permit. For general information regarding the certified visible emissions evaluator or the registration program, visit the ARB FAQ [http://www.arb.ca.gov/portable/perp/perpfact\\_04-16-15.pdf](http://www.arb.ca.gov/portable/perp/perpfact_04-16-15.pdf) or the PERP website <http://www.arb.ca.gov/portable/portable.htm>.

d. **STORM WATER CONTROL**

The permittee shall comply with all construction and post-construction storm water pollution prevention protocols as required by the County Engineering Services Division, and the California Regional Water Quality Control Board.

7.2 **ARCHEOLOGICAL FINDING**

In the event that archeological artifacts or human remains are discovered during construction, work shall cease in a 50-foot radius surrounding the area of discovery. The permittee shall contact the PBES Department for further guidance, which will likely include the requirement for the permittee to hire a qualified professional to analyze the artifacts encountered and to determine if additional measures are required.

If human remains are encountered during project development, all work in the vicinity must be halted, and the Napa County Coroner informed, so that the Coroner can determine if an investigation of the cause of death is required, and if the remains are of Native American origin. If the remains are of Native American origin, the permittee shall comply with the requirements of Public Resources Code Section 5097.98.

7.3 CONSTRUCTION NOISE

Construction noise shall be minimized to the greatest extent practical and feasible under State and local safety laws, consistent with construction noise levels permitted by the General Plan Community Character Element and the County Noise Ordinance. Construction equipment muffling and hours of operation shall be in compliance with the County Code. Equipment shall be shut down when not in use. Construction equipment shall normally be staged, loaded, and unloaded on the project site, if at all practicable. If project terrain or access road conditions require construction equipment to be staged, loaded, or unloaded off the project site (such as on a neighboring road or at the base of a hill), such activities shall only occur daily between the hours of 8 am to 5 pm.

7.4 CONSTRUCTION MITIGATION MEASURES [RESERVED]

7.5 OTHER CONSTRUCTION CONDITIONS APPLICABLE TO THE PROJECT PROPOSAL [RESERVED]

**8.0 TEMPORARY CERTIFICATE OF OCCUPANCY - PREREQUISITES**

A Temporary Certificate of Occupancy (TCO) may be granted pursuant to the County Code to allow the commencement of production activities prior to completion of all project improvements. Permittee shall comply with the following before a TCO is granted:

8.1 TEMPORARY OCCUPANCY

All life and safety conditions shall be addressed prior to issuance of a TCO by the County Building Official. TCOs shall not be used for the occupancy of hospitality buildings and shall not exceed the maximum time allowed by the County Code which is 180 days. Departments and/or agencies with jurisdiction over the project are authorized as part of the TCO process to require a security deposit or other financial instrument to guarantee completion of unfinished improvements.

**9.0 FINAL CERTIFICATE OF OCCUPANCY – PREREQUISITES**

Permittee shall comply with the following before a Final Certificate of Occupancy is granted by the County Building Official, which upon granting, authorizes all use permit activities to commence.

9.1 FINAL OCCUPANCY

All project improvements, including compliance with applicable codes, conditions, and requirements of all Departments and Agencies with jurisdiction over the project, shall be completed.

9.2 SIGNS

Detailed plans, including elevations, materials, color, and lighting for any winery identification or directional signs shall be submitted to the Department for administrative review and approval prior to installation. Administrative review and approval is not required if signage to be installed is consistent with signage plans submitted, reviewed and approved as part of this permit approval. All signs shall meet the design standards as set forth in the County Code. At least one legible sign shall be placed at the property entrance with the words "Tours and

Tasting by Prior Appointment Only” to inform the public of same. Any off-site signs allowed shall be in conformance with the County Code.

9.3 GATES/ENTRY STRUCTURES

Any gate installed at the winery entrance shall be reviewed by the PBES Department and the Fire Department to assure that the design allows large vehicles, such as motorhomes, to turn around if the gate is closed without backing into the public roadway, and that fire suppression access is available at all times. If the gate is part of an entry structure an additional permit shall be required pursuant to the County Code and in accordance with the Napa County Roads and Street Standards. A separate entry structure permit is not required if the entry structure is consistent with entry structure plans submitted, reviewed, and approved as part of this permit approval.

9.4 LANDSCAPING

Landscaping shall be installed in accordance with the approved landscaping plan.

9.5 ROAD OR TRAFFIC IMPROVEMENT REQUIREMENTS **[RESERVED]**

9.6 DEMOLITION ACTIVITIES **[RESERVED]**

9.7 GRADING SPOILS

All spoils shall be removed in accordance with the approved grading permit and/or building permit.

9.8 MITIGATION MEASURES APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY **[RESERVED]**

9.9 OTHER CONDITIONS APPLICABLE PRIOR TO ISSUANCE OF A FINAL CERTIFICATE OF OCCUPANCY

- a. Prior to the issuance of a Final Certificate of Occupancy, the directional sign required in COA 6.12(c) - Mitigation Measure Trans-1 shall be installed as approved.



A Tradition of Stewardship  
A Commitment to Service

David Morrison  
Director

## MEMORANDUM

To: Graham Hannaford, Planning	From: Jeannette Doss, Engineering <i>JD</i>
Date: May 17, 2018	Re: Kitoko Vineyards Winery Use Permit – Engineering CoA 3201 Atlas Peak Road, Napa CA P17-00373 APN: 033-010-034-000

The Engineering Division (Engineering) has reviewed the submittal package for the above proposed project, generally requesting the following:

*To establish a new winery with marketing plan and to construct new winery buildings, caves, outdoor covered crush pad, wastewater system, driveway, and parking lot and other associated site improvements..*

Based upon the information provided in the application, Engineering finds the application **complete** and recommends the following conditions of approval:

### OPERATIONAL CHARACTERISTICS

1. Any roadway, access drive, and parking area improvements that are required in order to comply with the latest edition of Napa County Road and Street Standards shall be completed **prior to execution** of any new entitlements approved under this Use Permit.

### PREREQUISITES FOR ISSUANCE OF PERMITS

2. All on site civil improvements including but not limited to the excavation, fill, general grading, drainage, curb, gutter, surface drainage, storm drainage, parking and drive isles, shall be constructed according to plans prepared by a registered civil engineer, which will be reviewed and approved by the Engineering Division of the Napa County Planning, Building, and Environmental Services Department (PBES) **prior to the commencement** of any on site land preparation or construction. Plans shall be wet signed and submitted with the building and/or grading permit documents at the time of permit application. A plan check fee will apply.
3. **Prior to issuance of a building or grading permit** the owner shall submit the necessary documents for Erosion Control as determined by the area of disturbance of the proposed development in accordance

with the Napa Countywide Stormwater Pollution Prevention program Erosion and Sediment Control Plan Guidance for Applicant and Review Staff dated December 2014.

4. **Prior to issuance of a building permit or grading permit** the owner shall prepare a Regulated Project Stormwater Control Plan (SCP) in accordance with the latest edition of the BASMAA Post-Construction Manual for review and approval by the Engineering Division in PBES.
5. **Prior to issuance of a building or grading permit** the owner shall demonstrate on the plans that all roadways, access driveways, and parking areas and how they will be improved to meet the requirements as outlined in the latest edition of the Napa County Road & Street Standards for Commercial development at the time of approval of this application (P17-00373).
6. **Prior to issuance of a building or grading permit** all newly proposed and/or modified loading areas, outdoor material storage area, trash areas, and processing areas, including but not limited to wine grape crushing/pressing, juice fermentation, blending and fining, filtration and bottling (including mobile bottling), shall be shown on the improvement plans. Areas shall be paved and performed indoors or under cover and graded to preclude stormwater run-on/runoff. The installation of storm drains in processing areas is prohibited. For processing areas that generate liquid wastes, slope the area to a drain an approved collection system.

#### **PREREQUISITES FOR TEMPORARY CERTIFICATE OF OCCUPANCY**

7. All roadway, access drive, and parking area improvements shall be completed **prior to issuance of temporary occupancy.**

**\*\* If no temporary occupancy is requested, then the above become requirements prior to final occupancy.**

#### **PREREQUISITES FOR FINAL CERTIFICATION OF OCCUPANCY**

8. A registered Civil Engineer shall submit to PBES, Engineering Division written certification of completion of grading in accordance with the approved grading plans prior to requesting final inspection of the building and/or grading permit. Certification shall include line grade, surface drainage, elevation, and location of permitted grading on the lot.
9. Operations and Maintenance Agreement for post construction Stormwater facilities must be legally recorded.
10. Site shall be completely stabilized to the satisfaction of the County Engineer prior to Final Occupancy.

**Any changes in use may necessitate additional conditions for approval.**

If you have any questions regarding the above items, please contact Jeannette Doss from Napa County Planning, Building, and Environmental Services Department, Engineering and Conservation Division, at (707) 259-8179 or by email at [Jeannette.Doss@countyofnapa.org](mailto:Jeannette.Doss@countyofnapa.org)



A Tradition of Stewardship  
A Commitment to Service

## MEMORANDUM

To: Charlene Gallina, Project Planner	From: Kim Withrow, Environmental Health Supervisor
Date: December 21, 2018	Re: Kitoko Vineyards Winery 3201 Atlas Peak Road APN: 033-010-034 Project #: P17-00373

Environmental Health Division staff has reviewed a revised application requesting approval to construct a winery and related improvements as described and depicted in application materials. This Division has no objection to approval of the application with the following conditions of approval:

*Prior to issuance of a building permit:*

1. Plans for the proposed alternative sewage treatment system(s) as described in the Wastewater Feasibility Study, dated September 2017, included with application materials shall be designed by a licensed Civil Engineer or Registered Environmental Health Specialist and be accompanied by complete design criteria based upon local conditions. No building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system will be approved until such plans are approved by this Division.

Please be advised-requirements for process wastewater treatment systems in Napa County are being reviewed and may require modification to comply with Regional Water Quality Control Board (RWQCB) minimum standards.

2. Permit(s) to construct the wastewater treatment system(s) improvements must be secured from this Division prior to approval of a building clearance (or issuance of a building permit) for any structure that generates wastewater to be disposed of by this system.
3. The water supply and related components must comply with the California Safe Drinking Water Act and Related Laws. This will require plan review and approval prior to approval of building permits. The technical report must be completed by a licensed engineer with experience in designing water systems. The preliminary technical report must be submitted to the Regional Water Quality Control Board staff a minimum of six (6)

months prior to beginning any water-related improvement in accordance with the California Health and Safety Code, Section 116527. Prior to occupancy, the owner must apply for and obtain an annual operating permit for the water system from this Division. The applicant must comply with all required monitoring and reporting.

4. Adequate area must be provided for collection of recyclables. The applicant must work with the franchised garbage hauler for the service area in which they are located, in order to determine the area and the access needed for the collection site. The garbage and recycling enclosure must meet the enclosure requirements provided during use permit process and be included on the building permit submittal. The designated area shall remain available and be properly maintained for its intended use.

*During construction and/or prior to final occupancy:*

5. Annual alternative sewage treatment system monitoring permit(s) must be obtained for the alternative sewage treatment system /private sewage disposal system prior to issuance of a final on the project. The applicant shall comply with required wastewater system monitoring.
6. Annual water system operating permit must be obtained prior to final occupancy.

*Upon final occupancy and thereafter:*

7. Proposed food service will be catered; therefore, all food must be prepared and served by a Napa County permitted caterer. If the caterer selected does not possess a valid Napa County Permit to operate, refer the business to this Division for assistance in obtaining the required permit prior to providing any food service.
8. Pursuant to Chapter 6.95 of the California Health and Safety Code, businesses that store hazardous materials above threshold planning quantities (55 gallons liquid, 200 cubic feet compressed gas, or 500 pounds of solids) shall obtain a permit, file an approved Hazardous Materials Business Plan to <http://cers.calepa.ca.gov/>, and be approved by this Division within 30 days of said activities.
9. The use of the wastewater absorption field/drain field area shall be restricted to activities which will not contribute to compaction of the soil with consequent reduction in soil aeration. Activities which must be avoided in the area of the septic system include equipment storage, traffic, parking, pavement, livestock, etc.
10. All solid waste shall be stored and disposed of in a manner to prevent nuisances or health threats from insects, vectors and odors.
11. All diatomaceous earth/bentonite must be disposed of in an approved manner. If the proposed septic system is an alternative sewage treatment system the plan submitted for review and approval must address bentonite disposal.



A Tradition of Stewardship  
A Commitment to Service

Planning, Building, & Environmental Services

1195 Third Street, Suite 210  
Napa, CA 94559  
www.co.napa.ca.us

Main: (707) 253-4417  
Fax: (707) 253-4336

David Morrison  
Director

To:	Graham Hannaford, Project Planner	From:	Marie Taylor, Building Inspector
Date:	November 29, 2017	Re:	Use Permit – Kitoko Vineyards Winery File # P17-00373 Address: 3201 Atlas Peak Road Napa, Ca. 94558 APN: 033-010-034

### Building Inspection Division; Planning Use Permit Review Comments

The plans provided for the Use Permit application P17-000373 do not provide enough information in sufficient detail to determine code requirements. A complete plan check will be performed at the time of application and plan submittal to the building division for required permits. The following are provided to prepare the applicant for some standard submittal requirements for the plan review of the building permit process.

Any existing structures and/or buildings on the property that will be demolished require a separate demolition permit issued by The Napa County Building Division prior to demolition. The applicant will be required to provide a J number form Bay Area Air Quality Management District at the time of application for the permit.

The site and associated buildings are required to be accessible to persons with disabilities. This includes but not limited to, parking, accessible path of travel from parking to all buildings and areas on site that are available to employees and the public. Plans must also include all accessibility features for the interior work. An Accessible Upgrade Worksheet must be submitted with plans as a part of the permit process.

Occupant load will determine occupancy types, exiting requirements, and restroom facilities.

Any change in occupancy or use will require building to comply with the requirements of the California Building Code for a new occupancy or use.

Should you have any questions, please contact Marie Taylor at (707) 299-1359





A Tradition of Stewardship  
A Commitment to Service

Napa County Fire Department  
Fire Marshal's Office  
Hall of Justice, 2nd Floor  
1125 3rd Street  
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna  
Fire Marshal

## MEMORANDUM

TO: Planning Division	DATE: 12/21/2017
FROM: Chase Beckman Fire Department	
SUBJECT: P17-00373	APN: 033-010-034

The Napa County Fire Marshal's Office has reviewed the submittal package for the above proposed project. The Fire Marshal approves as submitted and requires the following conditions to be incorporated as part of permit issuance.

1. All construction and use of the facility shall comply with all applicable standards, regulations, codes and ordinances at time of Building Permit issuance.
2. Beneficial occupancy will not be granted until all fire department fire and life safety items have been installed, tested and finalized.
3. The permittee and/or designee shall obtain a permit from the Fire Department for any temporary structures/canopies/tents utilized for authorized events.
4. Separate submittals required for Underground Fire Lines, Fire Pump, Automatic Fire Sprinklers, Fire Alarm Systems
5. All buildings, facilities, and developments shall be accessible to fire department apparatus by way of approved access roadways and/or driveways. The fire access road shall comply with the requirements of the Napa County Road & Street Standards.
6. Provide fire department access roads to within 150 feet of any exterior portion of the buildings as measured by an approved route around the exterior of the building or facility.
7. Roadways shall be a minimum of 20 feet in width with a 2 foot shoulder and 22 foot vertical clearance.
8. Driveways shall be a minimum of 10 feet in width with a 4 foot shoulder and 15 foot vertical clearance.



A Tradition of Stewardship  
A Commitment to Service

Napa County Fire Department  
Fire Marshal's Office  
Hall of Justice, 2nd Floor  
1125 3rd Street  
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna  
Fire Marshal

## MEMORANDUM

9. Turnouts shall be a minimum of 22 feet in width, 30 foot in length and 25 foot taper on each end.
10. Turnarounds are required on driveways and dead end roadways.
11. Grades for all roadways and driveways shall not exceed 16 percent.
12. Roadway radius shall not have an inside radius of less than 50 feet. And additional surface width of 4 feet shall be added to curves of 50-100 feet radius and 2 feet to curves of 100-200 feet radius.
13. Gates for driveways and/or roadways shall comply with the California Fire Code, section 503.5 and the Napa County Road & Street Standards and CA Fire Safe Regulations for projects within SRA.
14. Commercial - Water storage (for buildings not served by a public water system) and fire flow calculations shall be provided by a Certified State Licensed Civil Engineer, C-16 licensed contractor, or registered engineer indicating compliance with Table B105.2 through Table 105.4 of the Napa County Code Amendments.
15. Commercial - Approved steamer hydrants shall be installed within 250 feet of any exterior portion of the building as measured along vehicular access roads. Private fire service mains shall be installed, tested and maintained per NFPA 24 2013 edition.
16. Commercial - Fire Department Connections (FDC) for automatic sprinkler systems shall be located fully visible and recognizable from the street or fire apparatus access roads. FDC shall be located within 50 feet of an approved fire hydrant.
17. Commercial - The minimum main size of all fire hydrants shall be 6 inches in diameter. Piping shall be installed with C-900 class 200 piping or ductile iron or equivalent per NFPA 24, 2013 edition for the installation of Underground Fire Protection Mains
18. An automatic fire sprinkler system shall be installed in accordance with provisions set forth in the California Fire Code as amended by the County of Napa and the applicable National Fire Protection Association Standard. Automatic fire sprinkler systems shall be designed by a fire protection engineer or C-16 licensed contractor.



A Tradition of Stewardship  
A Commitment to Service

Napa County Fire Department  
Fire Marshal's Office  
Hall of Justice, 2nd Floor  
1125 3rd Street  
Napa, CA 94559

Office: (707) 299-1461

Garrett Veyna  
Fire Marshal

## MEMORANDUM

19. All buildings shall comply with California Fire Code, Chapter 10 Means of Egress requirements. Including but not limited to; exit signs, exit doors, exit hardware and exit illumination.
20. Provide 100 feet of defensible space around all structures.
21. Provide 10 feet of defensible space fire hazard reduction on both sides of all roadways of the facility.
22. Emergency responder radio coverage **in** new buildings. All new buildings shall have approved radio coverage for emergency responders within the building based upon the existing coverage levels of the public safety communication systems of the jurisdiction at the exterior of the building.
23. All cave development shall comply with CBC Section 436 as well as the Napa County Fire Marshal's Office Cave Development Guidelines.

Please note that the comments noted above are based on a Fire Marshal review only. There may be additional comments or information requested from other County Departments or Divisions reviewing this application submittal package. Napa County Fire Marshal's Office Development Guidelines can be found @ [www.countyofnapa.org/firemarshal](http://www.countyofnapa.org/firemarshal). Should you have any questions of me, contact me at (707)299-1467 or email at [chase.beckman@fire.ca.gov](mailto:chase.beckman@fire.ca.gov)