

“G”

Water Feasibility Study

WATER FEASIBILITY STUDY

ROBERT SINSKEY VINEYARDS

6320 Silverado Trail

Napa, California, 94558

APN 031-230-017

TABLE OF CONTENTS

System Description..... 1
Water Demand..... 2
 Proposed Water Uses..... 2
 Winery Process Water Demand..... 2
 Domestic Water Demand..... 3
Maximum Daily Demand (MDD) 4
Management..... 4
Financial 4

LIST OF ENCLOSURES

- Enclosure A: Overall Site Plan
- Enclosure B: Well Completion Reports
- Enclosure C: Wastewater Generation and Water Demand

SYSTEM DESCRIPTION

Robert Sinskey Vineyards is applying for a Use Permit (UP) Modification for the existing winery facility to increase employees and daily, by-appointment visitors. There are no proposed changes to the approved wine production of 143,000 gallons per year. Summit has prepared the following Water Feasibility Study, which evaluates the capacity of the existing water system to meet the proposed facility demands. The existing Public Water System (PWS ID CA-28-01042) serving the winery property can meet the facility demands and consolidation with another existing water system is not required as this is an existing public water system.

The existing winery parcel (APN: 031-230-017) consists of a winery/hospitality building, onsite vineyards, landscaping, and both a process wastewater (PW) and sanitary sewage (SS) treatment system (see Enclosure A for an overall site plan). Water sources for the property consist of three active groundwater wells. Well completion reports for these wells are included in Enclosure B. These three wells are rotated in use to supply the water demand of the winery (Table 1). Vineyard and landscape irrigation water demand is supplied using the treated effluent from the PW constructed treatment wetlands. All three wells are capable of being used to supplement the irrigation demand if required. Additionally, a fourth well located on an adjacent parcel also owned by Robert Sinskey Vineyards is capable of being used to meet water demand. This fourth well will be excluded from this analysis due to the three on-site wells being more than capable of meeting on-site water demand.

Table 1: Well source information.

Source	Primary Use	Status	Annular Seal Depth (ft)	Capacity (gallons/minute)
Well 1	Domestic/Process/Irrigation	Active	Unknown	12
Well 2	Domestic/Process/Irrigation	Active	21	30-40
Well 3	Domestic/Process/Irrigation	Active	51	30
TOTAL				72-82

The existing water treatment system includes an ozonation system (used to precipitate iron and manganese), media filtration, four concrete storage tanks (totaling 32,500 gallons), and a UV disinfection system prior to distribution to the winery. Additionally, treated PW water from the constructed wetlands is stored in two on-site storage tanks (totaling 132,000 gallons) for fire flows and irrigation. Approximately 69,000 gallons of this storage is reserved for irrigation of the on-site vineyards and landscaping.

With the proposed Use Permit modifications, the facility has an estimated average water demand of 3,886 gallons/day (gpd) and a peak demand of 6,036 gpd to meet all process and domestic needs (see Enclosure C). The anticipated water demand for the facility is expected to be met with the three existing wells that supply the potable water needs for the facility. Assuming a conservative 8-hour operational day cumulatively, the on-site wells are required to supply at least 13 gallons/minute (gpm) to meet peak demand. There are no major concerns of meeting this peak demand requirement considering wells 2 and 3 can meet this demand by themselves.

The maximum daily demand (MDD) for this facility is estimated to be 13,581 gpd based on the calculated peak demand of 6,036 gpd and a maximum peaking factor of 2.25. This MDD translates to a 28-gpm supply requirement for the on-site wells, over an 8-hour demand period. This demand can be met by using well 2 at maximum capacity (40 gpm) or a combination of wells 1, 2, or 3.

WATER DEMAND

The proposed UP modifications include an increase to the number of employees and daily, by-appointment visitors. Wine production volume will remain the same. The water demand increase is expected to correlate to the estimated wastewater generation flows for sanitary sewerage. Additionally, Robert Sinskey Vineyards will have to amend their Public Water System permit to account for the change from a Transient Non-Community (TNC) Water System to a Non-Transient Non-Community (NTNC) Water System. This change is the result of increasing the number of employees from 15 to 42.

Proposed Water Uses

Domestic water use at the facility will be based on the following needs:

- Process needs for production capacity of 143,000 gallons of wine per year
- Maximum Employees On-site = 42 per day
- Maximum Tasting Visitors = 257 per day (132 public and 125 by-appointment, 75 of which may have wine pairings)
- Every-Other-Week Marketing Event = 50 attendees max, 28 events per year
- Monthly Marketing Event = 80 attendees max, 12 events per year
- Biannual Marketing Event = 150 attendees max, 2 events per year

Winery Process Water Demand

Water demand for wine production is expected to correlate to the PW generated at the facility. Based on typical flow data from wineries of similar size and characteristics, the projected PW generation for wine production is calculated and summarized in Table 2.

Table 2: Existing and projected winery process water demand.

Parameter	Value	Units
Existing Annual Production	143,000	gal wine / year
PW Generation Rate ^a	5.0	gal PW / gal wine
Annual PW Flow	715,000	gal PW
Total Annual Winery Process Water Demand	715,000	gal water / year
Average PW Flow/Process Water Demand (based on 365 days/year)	1,960	gal PW / day
Peak PW Flow/Process Water Demand ^b	3,910	gal PW / day
Annual Production Water Demand	2.2	acre-ft water/year
Notes:		
a. Generation rate based on observations by Robert Sinskey Vineyards.		
b. The harvest month of September accounts for approximately 16.4% of the annual water demand in wineries of similar size		

The expected annual water use for the existing 143,000 gallons of wine/year production capacity is 715,000 gallons/year (2.2 acre-ft/year), with an average demand of 1,960 gpd, and a peak demand of 3,910 gpd. Winery process water demand will be provided by the existing domestic wells serving the public water system.

Domestic Water Demand

Domestic water use at the facility is determined based on the total number of employees, daily visitors, and event guests. SS generation is expected to be equivalent to the water demand for domestic uses. Using Napa County standards, the proposed domestic water demand for the winery facility is estimated using the following scenarios:

Daily Tasting w/o Events						
Employee (maximum on-site)	42	x	15	gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6	gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3	gpcd	=	546 gal/day
Total					=	1,626 gal/day
Daily Tasting w/ 5 days/week Event						
Employee (maximum on-site)	42	x	15	gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6	gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3	gpcd	=	546 gal/day
Event Guests w/ Pairings	50	x	6	gpcd	=	300 gal/day
Total					=	1,926 gal/day
Daily Tasting w/ Every-Other-Week Event						
Employee (maximum on-site)	42	x	15	gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6	gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3	gpcd	=	546 gal/day
Event Guests w/ Catered Dinners	50	x	10	gpcd	=	500 gal/day
Total					=	2,126 gal/day
Daily Tasting w/ Monthly Marketing Event						
Employee (maximum on-site)	42	x	15	gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6	gpcd	=	450 gal/day
Event Guests w/ Pairings	80	x	6	gpcd	=	480 gal/day
Total					=	2,106 gal/day
Daily Tasting w/ Biannual Event						
Employee (maximum on-site)	42	x	15	gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6	gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3	gpcd	=	546 gal/day
Event Guests w/o Pairings	150	x	3	gpcd	=	450 gal/day
Total					=	2,076 gal/day
ASSUMPTIONS						
1) From the conditions of approval of UPVMM #P11-00441-VMM, up to 75 of the tasting visitors are allowed pairings with their wine						
2) Food service is excluded for the biannual event. All other events may have food services as detailed in the conditions of approval for UPVMM #P11-00441-VMM						

The estimated average demand with increased employees and visitation is 1,626 gpd, and the estimated peak demand is 2,126 gpd. Domestic water demand will be provided by the existing domestic wells serving the public water system.

MAXIMUM DAILY DEMAND (MDD)

The MDD will occur during the facility’s peak months (September – October) and is determined based on the peak projected water demand for process and domestic water as follows below:

Table 3: Estimated MDD for Proposed UP Modification.

Demand	Flow (gpd)	8-hr Demand(gpm)
Process Water	3,910	8.1
Domestic Water	2,126	4.4
TOTAL	6,036	12.6

MAX DAY DEMAND

Estimated MDD 6,036 gpd X 2.25	=	13,581 Gallons
Existing Storage Onsite	=	32,500 Gallons

The existing public water system’s 32,500 gallons of treated water storage is still capable of meeting the new MDD associated with the proposed increase in use.

MANAGEMENT

Sinskey Vineyards, Inc., owns and operates Robert Sinskey Vineyards and is responsible for all finances, operations, compliance requirements, and establishment of policies. The facility’s domestic water system will be classified as non-transient, non-community and is managed by employees of the winery. Major repairs, replacements and other engineering and professional services are contracted out.


FINANCIAL

Sinskey Vineyards, Inc., is not currently encumbered by any judgements, liens, or other financial liability that would prevent the operation of the Robert Sinskey Vineyards water system. The operating and maintenance costs of the system are covered by the income from retail wine sales. There will be no expected primary financial impacts since the current water system has sufficient supply capacity to meet the increase in water demand.


Robert Sinskey Vineyards
Water Feasibility Study
November 5, 2019

SUMMIT ENGINEERING, INC.
Project No.: 2019156

**ENCLOSURE A
OVERALL SITE PLAN**



1 EXISTING SITE PLAN
A0.1 1" = 50'-0"



2 VICINITY MAP
A0.1 N.T.S.

Where:
Well A = Well 1
Well B = Well 2
Well C = Well 3

WELL D

WELL C

WELL B

WELL A



Robert Sinskey Vineyards
Water Feasibility Study
November 5, 2019

SUMMIT ENGINEERING, INC.
Project No.: 2019156

ENCLOSURE B
WELL COMPLETION REPORTS



BRELJE AND RACE LABORATORIES, INC.

Providing quality laboratory analysis since 1967

BACTERIOLOGICAL EXAMINATION OF WATER

REPORTED TO:
Robert Sinskey Winery
6320 Silverado Trail
Napa, CA 94558

DATE REPORTED: July 10, 2019
COLLECTED BY : AM/B&R Labs

Log Number	Date Collected	Date Set	Date Completed	Sample Source	Total Coliform	E. coli
719-14571	07/03/19	07/04/19	07/05/19	Tasting Room kitchen sink UV treated	Absent	Absent

Std. Mthds. 9223B Colilert

COPY SENT TO: NCHD

Called _____
Date _____

Approved By Jamil Lynch
BRELJE & RACE LABORATORIES, INC.

WELL # 2

TRIPPLICATE
Owner's Copy

STATE OF CALIFORNIA
THE RESOURCES AGENCY
DEPARTMENT OF WATER RESOURCES
WATER WELL DRILLERS REPORT

Do not fill in

No. 271120


Notice of Intent No. _____
Local Permit No. or Date 8-12-1988

State Well No. _____
Other Well No. _____

(1) OWNER: Name Sinskey Vineyards
Address 6320 Silverado Trail
City Napa, Ca. ZIP 94558

(2) LOCATION OF WELL (See instructions):
County Napa Owner's Well Number _____
Well address if different from above _____
Township 7 North Range 4 West Section 29
Distance from cities, roads, railroads, fences, etc. _____

A.P. # 31-230-02



(3) TYPE OF WORK:
New Well Deepening
Reconstruction
Reconditioning
Horizontal Well
Destruction (Describe destruction materials and procedures in Item 12)
(4) PROPOSED USE:
Domestic
Irrigation
Industrial
Test Well
Municipal
Other (Describe)

(12) WELL LOG: Total depth <u>423</u> ft. Completed depth <u>420</u> ft.	
from ft.	to ft. Formation (Describe by color, character, size or material)
0	25 Yellow Clay&Rock
25	45 Volcanic Ash-Sandy
45	61 Volcanic Ash-Volcanic Rock
61	80 Volcanic Ash, Fractured
80	90 Volcanic Ash, Fractured
90	100 Grey Volcanic Rock
100	105 Hard Volcanics
105	120 Grey Volcanic Ash 60% Sandstone 40%
120	140 Volcanic Ash
140	180 Volcanic Ash
180	200 Volcanic Ash 40% Sandstone 60%
200	280 Volcanic Ash
280	400 Grey Volcanic, Shale

WELL LOCATION SKETCH

(5) EQUIPMENT:
Rotary Reverse
Cable Air
Other Bucket

(6) GRAVEL PACK:
Yes No Size 3/8 pea
Diameter of bore 8 3/4
Packed from 21 to 420 ft.

(7) CASING INSTALLED:
Steel Plastic Concrete

(8) PERFORATIONS:
Type of perforation or size of screen

From ft.	To ft.	Dia. in.	Gage or Wall	From ft.	To ft.	Slot size
+1	423	5	E-480	75	175	1/8
				195	295	1/8
				335	419	1/8

(9) WELL SEAL:
Was surface sanitary seal provided? Yes No If yes, to depth 21 ft.
Were strata sealed against pollution? Yes No Interval _____ ft.
Method of sealing concrete

(10) WATER LEVELS:
Depth of first water, if known 160 ft.
Standing level after well completion 120 ft.

(11) WELL TESTS:
Was well test made? Yes No If yes, by whom? Driller
Type of test Pump Bailer Air lift
Depth to water at start of test 120 ft. At end of test 380 ft.
Discharge 75 gal/min after 4 hours Water temperature _____
Chemical analysis made? Yes No If yes, by whom? _____
Was electric log made Yes No If yes, attach copy to this report

Work started 8-10 19 88 Completed 8-17 19 88

WELL DRILLER'S STATEMENT:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Signed [Signature] (Well Driller)
NAME Huckfeldt Well Drilling
(Person, firm, or corporation) (Type or printed)
Address 2110 Penny Lane
City Napa, Ca. ZIP 94559
License No. 439746 Date of this report 10-5-1988

707-255-7044

JOE IMBODEN

WELL TESTING • FLOW PURITY • MINERAL

STATE LICENSE NO. C-61-150427

EST. 1946

1032 Pueblo Avenue

Napa, California
94558

TEST DATE

2/19/91

INVOICE NO.

1789

C
U
S
T
O
M
E
R

SINSKEY WINERY
6320 SILVERADO TRAIL
NAPA, CA

REALTOR

SALES PERSON

PARCEL NO.

31-230-02

ESCROW NO.

BUYER

SELLER

Well DIA-5" PVC. DEPTH-423' Level-320'

TIME	G.P.M	LEVEL
10:15	40	220' STATIC LEVEL
10:45	40	250'
11:15	38	260'
11:45	38	268'
12:15	38	280'
12:45	38	280'
1:15	38	280'
1:45	38	280'
2:15	38	280' STABILIZED LEVEL

Joe Imboden

NOTICE

UNDER THE MECHANICS LIEN LAW (CALIFORNIA CODE OF CIVIL PROCEDURE, SECTION 1181 ET SEQ.) ANY CONTRACTOR, SUBCONTRACTOR, LABORER, SUPPLIER OR OTHER PERSON WHO HELPS TO IMPROVE YOUR PROPERTY BUT IS NOT PAID FOR HIS WORK OR SUPPLIES HAS A RIGHT TO ENFORCE A CLAIM AGAINST YOUR PROPERTY. THIS MEANS THAT, AFTER A COURT HEARING, YOUR PROPERTY COULD BE SOLD BY A COURT OFFICER AND THE PROCEEDS OF THE SALE USED TO SATISFY THE INDEBTEDNESS. THIS CAN HAPPEN EVEN IF YOU HAVE PAID YOUR OWN CONTRACTOR IN FULL. IF THE SUBCONTRACTOR, LABORER, OR SUPPLIER REMAINS UNPAID.

A FINANCE CHARGE OF 1 1/2% PER MONTH (18% PER YEAR) WILL BE CHARGED COMMENCING 30 DAYS AFTER BILLING DATE.

\$200

ORIGINAL
File with DWR

STATE OF CALIFORNIA
WELL COMPLETION REPORT

Refer to Instruction Pamphlet

Page 1 of 1

Owner's Well No. 3

No. 197960

Date Work Began 7/12/93, Ended 8/1/93

Local Permit Agency County of Napa S.H.

Permit No. 33403 Permit Date 7/2/93

DWR USE ONLY — DO NOT FILL IN

STATE WELL NO./STATION NO.

LATITUDE LONGITUDE

APN/TRS/OTHER

GEOLOGIC LOG

ORIENTATION (∠) VERTICAL HORIZONTAL ANGLE _____ (SPECIFY)

DEPTH FROM SURFACE	
Ft.	to Ft.
0	4
4	26
26	88
88	109
109	127
127	130
130	200
200	222
222	280
280	290
290	475

DEPTH TO FIRST WATER _____ (Ft.) BELOW SURFACE

DESCRIPTION

Describe material, grain size, color, etc.

Ft.	to Ft.	DESCRIPTION
0	4	Top Soil
4	26	Loose Vol Ash Tan
26	88	Lite Brown Vol Ash
88	109	Lite Grey Sandstone Act
109	127	Hard Vol Rock
127	130	Grey Ash
130	200	Hard Fractured Rock
200	222	Grey Ash
222	280	Broken Blue Shale
280	290	Hard Rock
290	290	Clay Hard Shale
290	475	Shale Clay Mix


WELL OWNER

Name Sinsky Winery
Mailing Address 16320 Silverado Trail
Yountville Ca 94558
CITY STATE ZIP

WELL LOCATION

Address Same as above
City _____
County _____
APN Book 31 Page 230 Parcel 17
Township _____ Range _____ Section _____
Latitude _____ NORTH Longitude _____ WEST
DEG. MIN. SEC. DEG. MIN. SEC.

LOCATION SKETCH



ACTIVITY (∠)

- NEW WELL
- MODIFICATION/REPAIR
- Deepen
 - Other (Specify) _____
- DESTROY (Describe Procedures and Materials Under "GEOLOGIC LOG")
- PLANNED USE(S) (∠)
- MONITORING
- WATER SUPPLY
- Domestic
 - Public
 - Irrigation
 - Industrial
 - "TEST WELL"
 - CATHODIC PROTECTION
 - OTHER (Specify) _____

DRILLING METHOD Air FLUID _____

WATER LEVEL & YIELD OF COMPLETED WELL

DEPTH OF STATIC WATER LEVEL 119' (Ft.) & DATE MEASURED 8/6/93

ESTIMATED YIELD 60 (GPM) & TEST TYPE _____

TEST LENGTH 2 (Hrs.) TOTAL DRAWDOWN NA (Ft.)

* May not be representative of a well's long-term yield.

TOTAL DEPTH OF BORING 475 (Feet)

TOTAL DEPTH OF COMPLETED WELL 230' (Feet)

DEPTH FROM SURFACE		BORE-HOLE DIA. (Inches)	CASING(S)				DEPTH FROM SURFACE		ANNULAR MATERIAL				
Ft.	to Ft.		TYPE (∠)	MATERIAL / GRADE	INTERNAL DIAMETER (Inches)	GAUGE OR WALL THICKNESS	SLOT SIZE IF ANY (Inches)	Ft.	to Ft.	CE-MENT (∠)	BEN-TONITE (∠)	FILL (∠)	FILTER PACK (TYPE/SIZE)
0	60'	9"	✓	PVC 4FO	5"	200	-	0	51	✓			
60	100	8"	✓	" "	5"	200		51	475			✓	3/8 Pca
100	230	8"	✓	" "	"	200	.030						

ATTACHMENTS (∠)

- Geologic Log
- Well Construction Diagram
- Geophysical Log(s)
- Soil / Water Chemical Analyses
- Other _____

ATTACH ADDITIONAL INFORMATION, IF IT EXISTS.

CERTIFICATION STATEMENT

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief.

NAME D. Bess Pump a Well
(PERSON, FIRM, OR CORPORATION) (TYPED OR PRINTED)

ADDRESS 1115 MT George Ave CITY Napa STATE Ca ZIP 94558

Signed Dan Bess WELL DRILLER/AUTHORIZED REPRESENTATIVE DATE SIGNED 8/20/93 482027 C-57 LICENSE NUMBER

DATE 7/2/93
 FEE 6119.00
 RECEIPT NO. 32403
 BY [Signature]

A.P.# 31-230-17
 RECORD # _____

NAPA COUNTY
 DEPT. OF ENVIRONMENTAL MANAGEMENT
 APPLICATION & PERMIT TO CONSTRUCT A WATER WELL

NAME Sinsky Winery ADDRESS 6320 Silverado Trail
 (Owner) (Job Location)
 NAME Dave Bess PHONE # _____
 (Well Driller) ADDRESS _____

TYPE OF WORK
 New Class I PERMIT Test Hole Date Called In _____
 New Class II PERMIT _____ U.S.G.S. Map Received _____
 Well Reconstruction _____ Well Deepening _____ Horizontal Well _____
 Well Destruction _____ High Hazard _____ Low Hazard _____ Hand Dug _____

PROPOSED USE
 DOMESTIC TEST WELL _____ IRRIGATION Winery INDUSTRIAL _____ MUNICIPAL _____
 HOT WATER _____ (D.O.G. Clearance _____) OTHER _____

Sewage Disposal System (existing or proposed) Public _____ Individual _____ Private _____
 Distance from well to any part of nearest sewage disposal system > 100' (200+) feet.
 Septic System Location Determined By: _____
 Plot plan of well location received _____ County road setback _____ ft. from centerline.

WORKER'S COMPENSATION COVERAGE: (Check one of the following)
 A certificate of current Worker's Compensation Insurance coverage is presently on file with this office.
 A certificate of current Worker's Compensation Insurance is being filed with this application.
 I certify that in the performance of the work for which this permit is issued, I shall not employ any person in any manner so as to become subject to the Worker's Compensation laws in California.

TERMS OF PERMIT

- 1) Call at least 24 hours in advance to schedule an inspection.
- 2) Prior to receiving a Final Clearance on the well, a copy of the Department of Water Resources "Water Well Drillers Report" (DWR-188) must be returned to our Department.

Old Wells to be Destroyed: _____
 Other Remarks: No haz. sites within 300'; no flood plain.

[Signature]
 Signature of Applicant

7/2/93
 Date

FOR OFFICE USE ONLY

Date	By	Remarks
<u>7/2/93</u>	<u>Jm</u>	

Robert Sinskey Vineyards
Water Feasibility Study
November 5, 2019

SUMMIT ENGINEERING, INC.
Project No.: 2019156

ENCLOSURE C
WASTEWATER GENERATION AND WATER DEMAND

SUMMIT ENGINEERING, INC.	ROBERT SINSKEY VINEYARDS Water Availability Analysis Proposed Process Wastewater Flows (No Change)	PROJECT NO. 2019156 BY: JM CHK: GG
--------------------------	--	--

PROCESS WASTEWATER

Annual Volume

Annual Production (projected)		=	60,000 cases wine/year
Generation Rate (assumed) ^a		=	2.4 gal wine/case of wine
Annual Production	60,000 cases wine/year	x	2.4 gal wine/case of wine
		=	143,000 gal wine/year
Generation Rate (assumed) ^b		=	165 gal wine/ton grapes
Tons Crushed	143,000 gal wine/year	÷	165 gal wine/ton grapes
		=	867 tons grapes/year
Process Wastewater (PW) Generation Rate ^c	(assumed)	=	5.00 gal PW/gal wine
Annual PW Flow	143,000 gal wine/year	x	5.00 gal PW/gal wine
		=	<u>715,000 gal PW/year</u>

Average Day Flow

715,000 gal PW/year	÷	365 days	=	<u>1,959 gal PW/day</u>
			=	<u>1,960 gal PW/day</u>

Average Day Peak Harvest Month Flow

Assume:	1	16.4% of the PW flows are accounted for during September
	2	30 days in September

Peak Flow	$\frac{715,000 \text{ gal PW/year}}{30 \text{ days}}$	x	16.4%	=	<u>3,909 gal PW/day</u>
				=	<u>3,910 gal PW/day</u>

- a. 2.4 gallons of wine per case of wine
- b. 165 Gal wine per ton of grapes is used as a wine industry standard
- c. 6.0 gal of PW per gallon wine produced over the course of 1 year is based on the average of data from approximately 16 wineries
- d. Peak week tonnage was based on input from winery (for existing production)

SUMMIT ENGINEERING, INC.	ROBERT SINSKEY VINEYARDS Water Availability Analysis Proposed Sanitary Sewage Flows	PROJECT NO. 2019156 BY: JM CHK: GG
--------------------------	---	--

SANITARY SEWAGE

Daily Tasting w/o Events				
Employee (maximum on-site)	42 x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75 x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182 x	3 gpcd	=	546 gal/day
Total			=	1,626 gal/day
Daily Tasting w/ 5 days/week Event				
Employee (maximum on-site)	42 x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75 x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182 x	3 gpcd	=	546 gal/day
Event Guests w/ Pairings	50 x	6 gpcd	=	300 gal/day
Total			=	1,926 gal/day
Daily Tasting w/ Every-Other-Week Event				
Employee (maximum on-site)	42 x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75 x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182 x	3 gpcd	=	546 gal/day
Event Guests w/ Catered Dinners	50 x	10 gpcd	=	500 gal/day
Total			=	2,126 gal/day
Daily Tasting w/ Monthly Marketing Event				
Employee (maximum on-site)	42 x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75 x	6 gpcd	=	450 gal/day
Event Guests w/ Pairings	80 x	6 gpcd	=	480 gal/day
Total			=	2,106 gal/day
Daily Tasting w/ Biannual Event				
Employee (maximum on-site)	42 x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75 x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182 x	3 gpcd	=	546 gal/day
Event Guests w/o Pairings	150 x	3 gpcd	=	450 gal/day
Total			=	2,076 gal/day
ASSUMPTIONS				
1) Peak tasting visitation (500) will not occur on days with events				
1) From the conditions of approval of UPVMM #P11-00441-VMM, up to 75 of the tasting visitors are allowed pairings with their wine				
2) Food service is excluded for the biannual event. All other events may have food services as detailed in the conditions of approval for UPVMM #P11-00441-VMM				

SUMMIT ENGINEERING, INC. Consulting Civil Engineers	ROBERT SINSKEY VINEYARDS Water Availability Analysis Proposed Water Demand	PROJECT NO. 2019156 BY: JM CHK: GG
---	---	---

DOMESTIC WATER DEMAND

Daily Tasting w/o Events

Employee (maximum on-site)	42	x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3 gpcd	=	546 gal/day
Total				=	1,626 gal/day

Daily Tasting w/ 5/day/week Event

Employee (maximum on-site)	42	x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3 gpcd	=	546 gal/day
Event Guests w/ Pairings	50	x	6 gpcd	=	300 gal/day
Total				=	1,926 gal/day

Daily Tasting w/ Every-Other-Week Event

Employee (maximum on-site)	42	x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3 gpcd	=	546 gal/day
Event Guests w/ Catered Dinners	50	x	10 gpcd	=	500 gal/day
Total				=	2,126 gal/day

Daily Tasting w/ Monthly Marketing Event

Employee (maximum on-site)	42	x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3 gpcd	=	546 gal/day
Event Guests w/ Pairings	80	x	6 gpcd	=	480 gal/day
Total				=	2,106 gal/day

Daily Tasting w/ Biannual Event

Employee (maximum on-site)	42	x	15 gpcd	=	630 gal/day
Tasting Visitors w/ Pairings	75	x	6 gpcd	=	450 gal/day
Tasting Visitors w/o Pairings	182	x	3 gpcd	=	546 gal/day
Event Guests w/o Pairings	150	x	3 gpcd	=	450 gal/day
Total				=	2,076 gal/day

PROCESS WATER DEMAND

Average Day Flow	=	1,960 gal/day
Average, Day Peak Harvest Month Flow	=	3,910 gal/day

TOTAL WATER DEMAND

	<u>Average</u>		<u>Peak</u>	
	gal/day	gal/min ³	gal/day	gal/min ³
Domestic Water	1,926	4.0	2,126	4.4
Process Water	1,960	4.1	3,910	8.1
Total	3,886	8.1	6,036	12.6

Peaking Factor	=	2.25
MDD (based on peak demand)	=	13,581 gal/day

3) Over 8 hours per day	=	13 gpm (Peak)
		28 gpm (MDD)

Robert Sinskey Vineyards
Water Feasibility Study
November 5, 2019

SUMMIT ENGINEERING, INC.
Project No.: 2019156

Contact:
Gina Giacone
gina@summit-sr.com
(707) 636-9162

SUMMIT 

SUMMIT ENGINEERING, INC.

463 Aviation Blvd., Suite 200

Santa Rosa, CA 95403

707 527-0775

sfo@summit-sr.com