




Award Task Order for 66-inch Trunk Sewer Condition Assessment (CIP 19701)


Napa Sanitation District
Board of Directors Meeting
June 6, 2018



Background

- 15,400 LF (~3mi length)
- 66" RCP - unlined
- Criticality
 - Conveys over 90% of flow to treatment plant
 - Extends along east bank of Napa River
 - No redundancy


Background



- Constructed in 1967
 - Outfall line from Imola plant to oxidation ponds
- Began conveying untreated sewage in 1998
- Inspection history: 2001, 2012, 2017 (partial)



2017 Video Inspection





Manhole Entries

Internal Condition Assessment

- Characterize CCTV observations
 - Surface pH
 - Penetration testing
 - Sounding
 - Surface penetrating radar


Internal Condition



- Corrosion observed at all entries
- Structural deterioration along lower third
- Loss of concrete hardness and wall thickness



Internal Condition Varies along alignment





Test Pit Excavations

External Condition Assessment

- Soil Corrosivity
- Core sampling




External Condition




- Surface in good condition
- Remaining wall thickness of 4.6 to 4.8 inches
- Reinforcement type varies along length

Summary of Conditions



**Double cage
 (south test pit)**



**Elliptical
 (north test pit)**



Hydraulics

- 2007 CSMP identified that trunk requires capacity upgrade to convey peak flow
- Surcharging observed during storm events
- Peak flows are directly attributable to I/I
- Eight major I/I reduction projects have been completed; planned to continue at 2% of system annually

Alternatives

Corrosion Protection

- Chemical injection
- Crown spraying

Structural Rehabilitation

- Sliplining
- Cured-in-place pipe (CIPP)
- Spiral wound lining
- Mechanical point repairs

Replacement

- Open-cut
- Microtunneling

Increasing capital cost, schedule, environmental considerations



Advantages/Disadvantages

Corrosion Protection

- Lowest capital cost
- CEQA Categorical Exemption
- High O&M cost
- Non-structural

Structural Rehabilitation

- Most cost effective long-term
- Ability to phase construction
- Requires flow bypassing
- CEQA IS/MND
- Reduces capacity

Replacement

- Longest service life
- Ability to increase capacity
- Limited ability to phase construction
- Extensive design / permitting process
- Capital cost



Alternative Selection Factors

- Condition
 - Limits of structural deterioration
 - Continuity of wall loss
 - Sediment depths
- Hydraulics
 - Impact of sediment and wall loss
 - Long-term flow projections
 - Defining acceptable level of service

Condition
Assessment TO
Master Plan –
Phase I



Condition Assessment Task Order

- Conduct CCTV inspection and analysis along entire alignment of 66-inch trunk sewer
- Determine limits of structural deterioration and prioritize rehabilitation by segment
- Review CCTV footage of North Napa trunk sewer (11,700 LF unlined RCP) and prioritize rehabilitation
- Subsequent task orders include alternative selection, CEQA, permitting, and final design



Anticipated Schedule

Milestone	Date
Conduct CCTV Inspection	June 2018
Condition and Prioritization Reports	August 2018
Preliminary Design Report*	September 2018
Permitting and CEQA*	January 2019
Final Plans*	January 2019
Bidding	February 2019
Construction	Summer 2019

* To be completed under subsequent task orders; assumes CIPP



Recommendation

Authorize the General Manager to execute Task Order 1 with Woodard & Curran to provide engineering services to conduct a condition assessment and prioritization study for the 66-inch Trunk Sewer Rehabilitation Project (CIP 19701) in the amount of \$210,859.