



A Tradition of Stewardship
A Commitment to Service

Napa County Fire Department
Fire Marshal's Office
1199 Big Tree Road
St. Helena, CA 94574

Office: (707) 967-1419
Fax: (707) 967-1474

Pete Muñioa
Fire Marshal

INTER-OFFICE MEMORANDUM

TO: Mary Doyle
Conservation, Development and Planning Department

FROM: Brian Hampton
Fire Department

DATE: December 7, 2010

SUBJECT: Steven Stones Winery
P10-00372 APN# 025-080-031

SITE ADDRESS: 840 Meadowood Lane

The Napa County Fire Marshal's Office has reviewed the Use Permit application to increase gallonage from 1,000 to 4,500 gallons, increase visitors to 18/day increase facility square footage by 904 square feet, additional bathroom. The following items shall be incorporated as project conditions or mitigation measures if the commission approved the project.

- 1. All construction and use of the facility shall comply with all applicable standards, codes, regulations, and standards at the time of building permit issuance.**
2. Provide currently serviced and tagged 2A10BC fire extinguishers within 75 feet of travel distance from any portion of the facility. Fire extinguishers shall be mounted 3 1/2 feet to 5 feet to the top of the extinguisher.
3. Post numerical address at the public right of way visible from all directions of travel a minimum of 4-inches in height on a contrasting background. Numbers shall be reflective and/or illuminated.

If you have any questions and/or concerns in regards to the meaning of these conditions, please feel free to contact our office Monday through Thursday at 707-967-1423.