

INTER-OFFICE MEMO

TO: Kirsty Shelton
Conservation, Development, and Planning Department

FROM: Brian Hampton
Fire Department

DATE: June 27, 2011

SUBJECT: Envy Wines
P11-00163 APN# 017-210-027

SITE ADDRESS: 1170 Tubbs Lane

The Napa County Fire Marshal staff has reviewed the application to construct a 3500 square foot storage building with 1564 square feet of covered porches, and a 741 square foot covered crush pad. The following comments are required based on current codes and standards.

1. **All construction and use of the facility shall comply with all applicable standards, regulations, codes and ordinances at time of building permit issuance.**
2. Install steamer fire hydrants to within 250 feet of any exterior portion of the building as measured along approved vehicular access roads. Civil drawings shall be submitted to the Napa County Fire Marshal's Office for plan review and approval.
3. Install blue dot reflectors 12 inches of center line in front of all fire hydrants.
4. Install currently serviced and tagged fire extinguishers with a minimum rating of 2A10BC shall be mounted 3 1/2 feet to 5 feet to the top of the extinguisher. Fire extinguishers shall not exceed 75 feet of travel distance to any portion of the facility.
5. Install illuminated exit signs and emergency backup lighting throughout per the California Building Code 2007 edition.
6. Your fire flow for this project is 300 gallons per minute (GPM) for a 60 minute duration at 20 psi residual pressure. Provide 9,000 gallons of water dedicated for fire protection for the fire hydrants. Fire tanks shall be installed per NFPA 22 2002 edition. A UL listed fire pump conforming to NFPA 20 2002 edition may be required to meet the required fire flow for the project. Water storage for fire

sprinklers shall be in addition to the water storage to meet your required fire flows.

7. Approved access walkways shall be provided to all exterior doors and openings required by either the California Building Code or California Fire Code. A concrete walkway or other approved hard surface will meet the intent of the access walkway requirement.
8. The applicant shall properly identify all required fire lanes. Fire lanes shall be painted red with 4-inch white letters to read: "NO PARKING FIRE LANE" CVC 22500.1, stenciled every 30 feet on top of the curb.
9. All exit doors shall be operable without the use of a key or any special knowledge or effort.
10. The request for beneficial occupancy will not be considered until all fire and life safety issues have been installed, tested and finalized.
11. A complete set of building drawings and civil drawings shall be submitted to the Fire Department for plan review and approval.
12. Plans detailing compliance with the fire and life safety conditions of approval shall be submitted to the Napa County Fire Marshal's Office for plan review and approval prior to permit issuance.
13. The numerical address for the project shall be posted at the public right of way and shall be visible from both directions and shall be a minimum of 4-inches in height on a contrasting background and numbers shall be reflective and/or illuminated.
14. All structures exceeding 3,600 square feet shall be equipped with an automatic fire sprinkler system with water flow monitoring to a central receiving station shall be installed in conformance with NFPA 13, 2002 edition. Plans shall be submitted to the Napa County Fire Marshal's Office for plan review and approval prior to any installation.
15. All emergency vehicle access roads shall be installed per the Napa County Road and Street Standards.
16. All driveways and roads shall comply with the California Fire Code 2007 edition and Napa County Public Works road and street standards.
17. All gated entrances shall be provided with a KNOX KEY SWITCH for electronic gates and/or a KNOX PADLOCK for manual gates.

If you have any questions and/or concerns in regards to the meaning of these conditions, please feel free to contact our office Monday through Friday at 707-967-1423.